

AD-A085 298

CONSTRUCTION ENGINEERING RESEARCH LAB (ARMY) CHAMPAIGN IL P/O 9/3
AN ANALYSIS OF ELECTRICAL CONSUMPTION AT REPRESENTATIVE ARMY IN--ETC(U)
MAY 80 L M WINDINGLAND
CERL-IR-E-163

UNCLASSIFIED

NL

(OF)

AL
AD-A085 298

END

DATE

FILED

7-80

DTIC

INTERIM REPORT E-163

construction
engineering
research
laboratory



United States Army
Corps of Engineers
Serving the Army
Serving the Nation

INTERIM REPORT E-163
May 1980
Methods to Reduce Electrical Consumption

AN ANALYSIS OF ELECTRICAL CONSUMPTION AT
REPRESENTATIVE ARMY INSTALLATIONS

ADA 085298

AN ANALYSIS OF ELECTRICAL CONSUMPTION

by
L. M. Windingland

DTIC
ELECTE
JUN 10 1980
S D D

DOC FILE

80 6 9 1 64



Approved for public release; distribution unlimited.

The contents of this report are not to be used for advertising, publication, or promotional purposes. Citation of trade names does not constitute an official indorsement or approval of the use of such commercial products. The findings of this report are not to be construed as an official Department of the Army position, unless so designated by other authorized documents.

***DESTROY THIS REPORT WHEN IT IS NO LONGER NEEDED
DO NOT RETURN IT TO THE ORIGINATOR***

REPORT DOCUMENTATION PAGE		READ INSTRUCTIONS BEFORE COMPLETING FORM
1. REPORT NUMBER L-IR-E-163	2. GOVT ACCESSION NO. 4D-A085 398	3. RECIPIENT'S CATALOG NUMBER
4. TITLE (and Subtitle) ANALYSIS OF ELECTRICAL CONSUMPTION AT REPRESENTATIVE ARMY INSTALLATIONS.		5. TYPE OF REPORT & PERIOD COVERED INTERIM <i>reports</i>
6. PERFORMING ORG. REPORT NUMBER		7. CONTRACT OR GRANT NUMBER(s)
8. AUTHOR(s) M. Windingland		9. PROGRAM ELEMENT, PROJECT, TASK AREA & WORK UNIT NUMBERS 4A762731AT41-G-004
10. PERFORMING ORGANIZATION NAME AND ADDRESS S. ARMY INSTRUCTION ENGINEERING RESEARCH LABORATORY J. Box 4005, Champaign, IL 61820		11. REPORT DATE May 1980
12. CONTROLLING OFFICE NAME AND ADDRESS		13. NUMBER OF PAGES 77
14. MONITORING AGENCY NAME & ADDRESS (if different from Controlling Office)		15. SECURITY CLASS. (of this report) Unclassified
15a. DECLASSIFICATION/DOWNGRADING SCHEDULE		
16. DISTRIBUTION STATEMENT (of this Report) proved for public release; distribution unlimited.		
17. DISTRIBUTION STATEMENT (of the abstract entered in Block 20, if different from Report)		
18. SUPPLEMENTARY NOTES opies are obtainable from National Technical Information Service Springfield, VA 22151		
19. KEY WORDS (Continue on reverse side if necessary and identify by block number) electric power energy consumption military facilities		
20. ABSTRACT (Continue on reverse side if necessary and identify by block number) This report describes an analysis of monthly and daily electrical energy consumption data collected over 2 years from 8 electrical feeders at Fort Carson, CO, and 20 different Army buildings at Fort Carson and at Fort Belvoir, VA. The work was conducted to determine why electrical energy consumption has been increasing at Army installations, and to provide a basis for determining methods to reduce consumption. <i>next page</i>		

Block 20 continued.

→ It was determined that many Army buildings have a high minimum electrical usage (minimum demand) that amounts to up to 75 percent of total annual consumption. Tables and graphs are provided which amplify the significance of this minimum demand. It was concluded that a shift from emphasizing a reduction in occupant usage of electrical energy to a concentrated effort to minimize the continuous electrical usage caused by building operation and heating, ventilating, and air-conditioning (HVAC) systems should reduce electrical consumption at Army installations.

↑

UNCLASSIFIED

FOREWORD

This work was performed for the Directorate of Military Programs, Office of the Chief of Engineers (OCE), under Project 4A762731AT41, "Design, Construction and Operation and Maintenance Technology for Military Facilities," Technical Area G, Work Unit 004, "Methods to Reduce Electrical Consumption." Mr. Homer Musselman, DAEN-MPO-U, was the OCE Technical Monitor.

The work was performed by the Energy Systems Division (ES), U.S. Army Construction Engineering Research Laboratory (CERL). Mr. R. G. Donaghy is Chief of ES. Appreciation for his support during building field surveys is expressed to Hank Gianilliat, U.S. Army Facilities Engineering Support Agency, Technical Support Division.

COL Louis J. Circeo is Commander and Director of CERL and Dr. L. R. Shaffer is Technical Director.

Accession For	
NTIS GRA&I	<input checked="checked" type="checkbox"/>
DDC TAB	<input type="checkbox"/>
Unannounced	<input type="checkbox"/>
Justification	
By _____	
Distribution/	
Availability Codes	
Dist.	Avail and/or special
A	

CONTENTS

	<u>Page</u>
DD FORM 1473	1
FOREWORD	3
LIST OF TABLES AND FIGURES	5
1 INTRODUCTION.....	7
Background	
Objective	
Approach	
Mode of Technology Transfer	
2 DATA COLLECTION PROCEDURES.....	10
Selection of Installations for Study	
Electrical Feeder Energy-Use Data	
Building Electrical Energy-Use Data	
Electrical Energy Conservation Programs	
Installation Observations and Onsite Measurements	
3 DATA ANALYSES AND FINDINGS.....	12
Feeder Data Analyses	
Building Data Analyses	
Summary	
4 OPERATIONAL FINDINGS.....	19
Fort Belvoir	
Fort Carson	
Discussion	
General Trends Indicated by Representative Installation	
Analyses	
Summary	
5 CONCLUSIONS.....	24
TABLES	25
FIGURES	53
APPENDIX: Building Inspection Procedures	67
DISTRIBUTION	

TABLES

<u>Number</u>		<u>Page</u>
1	Building Locations and Functions	25
2	Monthly Feeder Electrical Consumption -- July 1976 through June 1977	26
3	Monthly Feeder Electrical Consumption -- July 1977 through June 1978	27
4	Daily Feeder Electrical Consumption	28
5	Fort Carson Weather Parameters	29
6	Weather Parameters (Daily Data)	29
7	Heating and Cooling Degree Days	30
8	Building 1430 -- Fort Carson	31
9	Building 7300 -- Fort Carson	32
10	Building 1525 -- Fort Carson	33
11	Building 7304 -- Fort Carson	34
12	Building 1953 -- Fort Carson	35
13	Building 811 -- Fort Carson	36
14	Building 1219 -- Fort Carson	37
15	Building 1971 -- Fort Carson	38
16	Building 1230 -- Fort Carson	39
17	Building 2492 -- Fort Carson	40
18	Building 2992 -- Fort Carson	41
19	Building 216 -- Fort Belvoir	42
20	Building 20 -- Fort Belvoir	43
21	Building 1099 -- Fort Belvoir	44
22	Building 2120 -- Fort Belvoir	45
23	Building 508 -- Fort Belvoir	46
24	Building 211 -- Fort Belvoir	47
25	Building 1928 -- Fort Belvoir	48
26	Building 1200 -- Fort Belvoir	49
27	Building 1949 -- Fort Belvoir	50
28	Fort Belvoir -- ₃ Electrical Energy Consumption (in MWh x 10 ³) for FY77 to FY79	51
29	Fort Carson -- ₃ Electrical Energy Consumption (in MWh x 10 ³) for FY77 to FY79	52

FIGURES

<u>Number</u>		<u>Page</u>
1	Fort Carson Electrical Distribution System	53
2	Monthly Feeder Profile -- Winter (Fort Carson)	55
3	Buildings and Systems Served by Feeder 2 -- Fort Carson	57
4	Monthly Feeder Profile -- Summer (Fort Carson)	59
5	Monthly Electrical Profile -- Winter (Building 1430)	60
6	Monthly Electrical Profile -- Summer (Building 1430)	61

Figures (Cont'd)

<u>Number</u>		<u>Page</u>
7	Monthly Electrical Profile -- Winter (Building 1953)	62
8	Monthly Electrical Profile -- Winter (Building 2492)	63
9	Monthly Electrical Profile -- Winter (Building 2992)	64
10	Monthly Electrical Profile -- Summer (Building 2492)	65
11	Monthly Electrical Profile -- Summer (Building 2992)	66

AN ANALYSIS OF ELECTRICAL CONSUMPTION AT REPRESENTATIVE ARMY INSTALLATIONS

1 INTRODUCTION

Background

The Facilities Engineering Annual Summary of Operations (FY75 through FY78) indicated that Army installations world-wide spent \$275 million for electrical energy in FY78.¹ Of this amount, \$173 million was spent in the continental United States. This electrical energy expenditure is of great concern to installation commanders and Major Commands (MACOMs). The Army must reduce the consumption of electrical energy in its buildings, both to minimize total dollar expenditures and to comply with the Presidential Executive Order to reduce average energy use in existing buildings by 20 percent by the year 1985 (based on consumption levels established during FY75). However, several Army MACOMs have increased electrical energy use since the FY75 baseline was established. Although the Army has had substantial success in reducing its thermal energy requirements, efforts to reduce electrical energy consumption have been less than satisfactory and additional emphasis on electrical conservation appears necessary. Records for FY78 show that the use of electricity at Army installations has increased by 6.6 percent since FY75; since FY75, the cost of electricity has increased 56 percent. Therefore, electrical energy consumption remains a significant Army expenditure in terms of both dollars and energy.

Although Facilities Engineers and MACOMs have placed considerable emphasis on reducing electrical energy consumption, they have yet to realize major savings. Therefore, the U.S. Army Construction Engineering Research Laboratory (CERL) was asked to help Facilities Engineers determine why electrical energy consumption is increasing and to develop methods of reducing electrical consumption on Army installations.

Objective

The overall objective of this study is to (1) describe how electrical energy is being used on military installations, (2) describe the major causes for changes in electrical energy usage, and (3) suggest operational changes and equipment techniques that will reduce electrical energy consumption which Facilities Engineers can use to plan and execute effective electrical conservation programs.

¹ Facilities Engineering, Annual Summary of Operations, Fiscal Years 1976 through 1978 (Department of the Army, Office of the Chief of Engineers, 1979).

The objective of this report is to document (1) and (2) above (Phase One of the overall research effort).

Approach

Phase One of this study consisted of the following steps:

1. Representative Army installations were selected for electrical energy consumption analysis. Data from these analyses were used to draw general conclusions about similar operations and problems Army-wide.
2. General information on installation consumption was obtained.
3. Installation electrical energy consumption by feeder area was analyzed.
4. End-use electrical energy consumption was determined by performing short-term onsite measurements of lighting, equipment, air conditioning, and other individual electrical consumers.
5. Installation procedures and techniques currently used to reduce electrical energy consumption were observed and evaluated.
6. The effects of occupant activities and the lifestyle of building users on electrical energy consumption were determined.
7. A method for Facilities Engineers to use in performing building inspections to eliminate electrical energy waste was developed.
8. How electrical energy is being used on the selected installations was described and probable causes for increases or decreases in annual consumption were determined.

Phase Two of this study will:

1. Evaluate selected installations to determine their potential for electrical energy reduction.
2. Prepare recommendations for retrofit opportunities or probable operational changes that would be necessary to reduce electrical energy consumption.
3. Investigate electrical power demands and the power cost/billing structure to determine if there is potential for savings with peak electrical demand saving techniques or power factor correction.

4. Describe how electrical energy is being used, determine the impact of demand charges, identify major causes of electrical energy use increases or decreases, evaluate the potential for electrical energy reduction, suggest methods for achieving this reduction, and analyze the impact that these recommendations will have on Army installations.

Mode of Technology Transfer

The information gathered during Phases One and Two of this study will be used to prepare an Engineer Technical Note describing recommended methods and procedures for reducing electrical energy consumption on Army installations.

2 DATA COLLECTION PROCEDURES

Selection of Installations for Study

The installations selected for this electrical consumption study were primarily those that had electrical energy-use data detailed enough to be analyzed. Most installations have little more than a master meter at the substation entering the installation. However, in 1975, an Army metering project was set up to monitor more than 100 Army installation buildings for electrical and thermal energy demands; several installation feeders were also monitored.² These data, gathered on an hourly basis, are generally available for a 2-year period beginning in FY77. The two installations selected for analysis in this study are participants in that energy monitoring project: Fort Belvoir, VA, a TRADOC installation; and Fort Carson, CO, a FORSCOM installation. Both of these installations, according to the Facilities Engineering Annual Summary of Operations Report (FY75 through FY78), showed an increase in electrical energy use from the period FY75 to FY78.

Electrical Feeder Energy-Use Data

Most installations purchase their electrical energy from local communities; it is normally fed at a high voltage to a single substation and distributed from that substation on feeders to various sections of the installation. The feeders analyzed as part of this study are part of the Fort Carson distribution system, which consists of two main substations that step down the 34.5 kV incoming service for distribution throughout the installation. (Service is supplied by the City of Colorado Springs, CO.) Figure 1 is a one-line diagram showing the electrical distribution system at Fort Carson.

Under the energy monitoring project, the eight feeders being served by Substation No. 1 are being monitored. Energy-use data from meters installed on the individual feeder lines served by Substation No. 1 were analyzed during this study to identify seasonal, extremely high or low consumption, or load shifting -- if any -- in electrical energy usage. If any particular areas of the installation exhibited such trends, a further analysis was then performed and a breakout made of the electrical energy usage by building or by building function (i.e., lighting,

² B. Sliwinski, D. Leverenz, and L. M. Windingland, Fixed Facilities Energy Consumption Investigation -- Data Analysis, Interim Report E-143/ADA066513 (U.S. Army Construction Engineering Research Laboratory [CERL], February 1979); L. M. Windingland, R. J. Sliwinski, Fixed Facilities Energy Consumption Investigation -- Initial Energy Data, Interim Report E-120 (CERL, January 1978); and L. Windingland, B. Sliwinski, and A. Mech, Fixed Facilities Energy Consumption Data User's Manual, Interim Report E-127/ADA051678 (CERL, February 1978).

air conditioning [AC] equipment); particular building types predominant within the feeder area would also be analyzed (by surveys and metering) to determine their contribution to the total feeder consumption.

Building Electrical Energy-Use Data

Twenty buildings were selected for analysis. The buildings were selected based on their repetitive construction (numerous similar buildings on the installation) and on the availability of complete actual electrical consumption data for a 2-year period. These buildings, their function and location are listed in Table 1. The total consumption by month for 2 fiscal years was determined from energy-monitoring project data. A determination of the AC load on the building, the base load on the building, building peak and minimum demands, seasonal changes in energy usage, and evidence of increases or decreases in electrical energy consumption for the building were identified. Energy-use data were extracted both on an hourly basis (for daily analysis), and on a monthly basis (for total consumption).

Electrical Energy Conservation Programs

Army installations are required to have energy conservation programs. The installations studied had prepared a supplement to Army Regulation AR 11-27 to cover the majority of energy conservation actions.³ All actions that the installations had taken to encourage electrical energy conservation were noted, and observations were made to determine their effectiveness.

Installation Observations and Onsite Measurements

Each of the selected installations was visited to determine the effectiveness of its electrical energy conservation program. Discrepancies between items within each installation's energy conservation program and operational or occupant usage of facilities were noted. Short-term, onsite measurements were made at several facilities to determine actual AC consumption, lighting consumption, and other equipment consumption.

³ Army Energy Program, Army Regulation (AR) 11-27 (Department of the Army, 20 July 1976).

3 DATA ANALYSES AND FINDINGS

Feeder Data Analyses

Tables 2 and 3 show the July 1976 through June 1978 electrical consumption for the eight monitored feeders at Fort Carson, CO. It can be seen that fairly wide fluctuations in usage occur between individual feeders, and on a month-to-month basis for any particular feeder. The tables show that there are no clear and consistent seasonal trends or evidence of consistent increases or decreases in consumption by individual feeder. It appears from the tables that loads are switched from one feeder to another, which would explain some of the major differences in monthly consumption (e.g., Table 3 shows more than a 1-million kWh difference for the month of November between Feeders 3 and 4). It was expected that major consumers on the installation could be determined by observing these data. With that information, reasons why and how electric energy was being used would be better defined. However, the inconsistency, nonevidence of trends, and missing data caused the analyses of monthly feeder consumption data to be inconclusive.

An analysis of daily consumption for the feeders produced more interesting results. Table 4 shows the daily consumption, peak hourly consumption, minimum hourly consumption, and minimum percent of daily total for the feeders at Fort Carson. Included in the table are values for winter and summer days, for both a weekend and a weekday. Note that the minimum demand consumption (extended over 24 hours) is a significant portion of the total consumption. For example, Feeder 1 on Sunday, 11 June 1978, consumed 20,950 kWh, had a maximum hourly consumption of 1002 kW, and a minimum hourly consumption of 672 kW. When this minimum demand is multiplied by 24 hours, the result is 16,128 kWh -- 77 percent of the total daily consumption. This value, which might be termed a "minimum baseline consumption," varies from 54 percent to 91 percent and averages 71 percent for the data listed in Table 4. The weekend (Sunday) baseline averages 75 percent; the weekday (Tuesday) baseline, as might be expected, is lower (68 percent). These values, which are different for each feeder and probably change slightly every day, indicate that the installation consumes approximately 70 percent of its electrical energy during minimum operational status. The data conversely indicate that approximately 30 percent of electrical energy is consumed by operational functions. Figure 2 shows the winter monthly profile for one of the feeders at Fort Carson. The hourly demand of electricity being used along this feeder is shown for 1 to 25 January 1978. The total consumption for this period is 447,300 kWh; the minimum hourly demand is 470 kW, and the maximum hourly demand is 1360 kW. The minimum percentage of total consumption is 63 percent. This value is obtained by multiplying the minimum demand (470 kW) by the number of hours of monitoring and dividing by the total consumption. In this case, $470 \text{ kW} \times 24 \text{ hours/day} \times 25 \text{ days} \div 447,300 \text{ kWh} = 0.63$. This means the area under the curve bounded by the minimum demand consists of 63 percent (282,000 kWh) of the total area (447,300 kWh) under the curve.

Minimum demand consumption can also be expressed as continuous demand on the feeder. The feeder shown in Figure 2 serves 85 installation buildings through 56 transformer banks of 3280 kVA total capacity. Figure 3 shows the buildings and systems served by Feeder 2. Figure 4 shows the profile for a summer month -- 6 to 30 June 1978. This profile shows a 54 percent minimum consumption. Figures 3 and 4 indicate that substantial electrical energy is being consumed by the high minimum baseline demand. Table 5 shows the weather conditions at Fort Carson for the days listed in Table 4, including heating degree days (HDD) and cooling degree days (CDD). For the four days listed in Table 4, the installation minimum demand occurs between 2 and 4 AM; the maximum demand consistently occurs at 2 PM.

Building Data Analyses

Twenty buildings were analyzed for their annual and daily electrical consumption. The monthly electrical consumption data, weekday and weekend daily consumption, hourly maximum demand, hourly minimum demands, and physical data for these buildings are shown in Tables 8 through 27. Each building will be discussed separately.

Table 6 shows the weather parameters at Fort Carson and Fort Belvoir for the days daily data were reported. Included in Table 6 are daily maximum and minimum temperatures, daily average temperatures, and HDD or CDD as reported by the National Oceanic Atmospheric Administration (NOAA), National Climatic Center, Ashville, NC. Table 7 shows the corresponding HDD and CDD associated with the monthly consumption data.

Table 8 shows data from Building 1430, an administration building at Fort Carson. This building consumes, on the average, 0.0315 kWh/sq ft/day. The monthly consumption data in Table 8 show no significant differences between 1976 to 1977 and 1977 to 1978 data. Note that the building exhibits a fairly large minimum base demand -- about 32 kW (768 kWh daily); i.e., 58 percent of the energy consumed in the building is not directly related to occupancy. The difference between the minimum and maximum hourly demands for weekdays can be largely attributed to lighting and equipment, particularly telecommunications equipment. This shows up clearly in the connected equipment kW load listed in Table 8.

Cooling season consumption for Building 1430 is slightly higher than heating season consumption. The maximum hourly weekday consumption in the summer is 100 kW and the maximum winter weekday demand is 90 kW. The monthly consumption data also show that summer consumption is about 3000 kWh/month higher than winter consumption.

Figure 5 is a plot of the electrical energy consumption for 7 to 27 January 1978. Values corresponding to minimum, maximum, and total consumption are included for clarity. Figure 5 compares minimum demand and daily usage to total consumption. Figure 6 shows a similar plot for summer energy consumption for 7 to 21 July 1978.

Table 9 shows data for Building 7300, the officer's open mess facility at Fort Carson. This building consumes, on the average, 0.070 kWh/sq ft/day. Cooling season consumption for Building 7300 shown in the monthly consumption data in Table 9 is higher than heating season consumption. The difference between summer consumption and winter consumption is about 20,000 kWh/month. The minimum hourly demand during unoccupied periods is 55 percent of the daily total consumption. Much of this minimum demand can be attributed to the refrigeration equipment and the heating, ventilating, and air-conditioning (HVAC) system used within the facility. (Further study, including onsite visits and equipment monitoring, would be necessary to define the exact cause of the minimum load during unoccupied periods.) The monthly consumption data also show that this facility has reduced its energy consumption by roughly 10 percent from 1977 to 1978. Note that the AC load is a substantial portion of the summer energy consumption, as indicated by the AC equipment connected load of 48 kW listed in Table 9.

Table 10 shows data for Building 1525, the commissary at Fort Carson. This building consumes, on the average, 0.09 kWh/sq ft/day. The monthly electrical consumption data in Table 10 show that summer consumption is substantially higher than winter consumption because of the large amount of AC equipment (138 kW connected load) installed in the building. The seasonal consumption data show that the building consumes about 65 percent of its energy on a continuous basis. Note that on Sundays (when the building does not have customers) there is still substantial daily electrical consumption (5620 kWh in the winter and 7010 kWh in the summer). This is primarily caused by the building's refrigeration loads.

Table 11 shows data for Building 7304, a bachelor officer's quarters at Fort Carson. Building 7304 consumes, on the average, 0.0137 kWh/sq ft/day. The monthly consumption data in Table 11 show that this building's electrical energy use increased during the winter months. Since the building is not cooled, this increase can be attributed to heating system pumps and fans and additional lighting required by shorter daylight hours. The building did not show any substantial increase or decrease in consumption between 1977 and 1978. Although this building does not have a profile similar to operational-type buildings, the hourly minimum most often occurs in the early morning. However, the minimum usage -- predominantly heating and cooling equipment -- is a substantial (60 percent) portion of the total daily consumption.

Table 12 shows data for Building 1953, a bachelor enlisted quarters at Fort Carson. Building 1953 consumes, on the average, 0.0179 kWh/sq ft/day. It is served from a central plant which supplies both hot and chilled water to the HVAC system. The data show a slight increase in electrical energy consumption during the winter months. This increase can be attributed to fewer daylight hours, i.e., a need for more lighting, and higher use of heating system fans than in the cooling season. The minimum demand (12 kW) over a 24-hour summer period was 70 percent of the daily total usage. Figure 7 shows the consumption profile for 1

to 25 January 1978. This profile is considerably different from Building 1430, the administration building; Building 1953's profile has less pronounced peaks and smaller variations between weekends and weekdays.

Table 13 shows data for Building 811, a bachelor enlisted quarters with dining facilities at Fort Carson. Building 811 consumes, on the average, 0.015 kWh/sq ft/day. The monthly consumption data in Table 13 show a slight decrease in electrical energy use from 1977 to 1978. These data also show that there is no consistent seasonal variation in monthly electrical energy consumption. This building also has a substantial minimum hourly demand (66 percent of the daily total). The difference between the minimum hourly demand and the maximum hourly demand can be attributed to food preparation in the dining portion of the building, occupant lighting, and laundry.

Table 14 shows data for Building 1219, a bachelor enlisted quarters at Fort Carson. Building 1219 consumes, on the average, 0.0093 kWh/sq ft/day. The monthly consumption data in Table 14 do not show any major variation between summer and winter consumption. The minimum demand constitutes 60 percent of the annual consumption. A 1 kW reduction in the minimum demand (8760 kWh/year) would create a 5 percent reduction in annual consumption for Building 1219.

Table 15 shows data for Building 1044, a bachelor enlisted quarters at Fort Carson. Building 1044 consumes, on the annual average, 0.012 kWh/sq ft/day. The monthly consumption data in Table 15 show that a significant decrease in electrical energy consumption occurred between 1976 to 1977 and 1977 to 1978 data. (The reason for this decrease has not been determined.) Building 1044's seasonal consumption data show that cooling season consumption is considerably higher than heating season consumption. This increase can be attributed to the operating hours of the fans used for cooling; the building is heated by fin tube radiation around the building's inside perimeter.

Table 16 shows data for Building 1230, a recreation center at Fort Carson. Building 1230 consumes, on the average, 0.014 kWh/sq ft/day. The monthly consumption data in Table 16 show no significant variations from 1977 to 1978. Summer consumption is considerably higher than winter consumption, mainly caused by no cooling equipment. This building consumes roughly 67 percent of its energy during the nonoperational mode. Therefore, the amount of consumption which can be attributed to building occupants is 33 percent of the total annual consumption.

Tables 17 and 18 show data for Buildings 2492 and 2992, identical maintenance facilities at Fort Carson. Buildings 2492 and 2992 have an annual average consumption of 0.032 and 0.028 kWh/sq ft/day, respectively. Although these two facilities are identical in function, size, and equipment, Building 2992 consumes roughly 20 percent less electrical energy than Building 2492. The major reason for this difference is the minimum hourly consumption of the two facilities. Building 2492 has a weekday minimum of about 20 kW in the summer and 40 kW in the winter;

Building 2992 has a 6 kW minimum in the summer and a 30 kW minimum in the winter. There is no electrical usage in the building that pertains directly to the maintenance function, i.e., no battery chargers, welders, or electric tools are being used to maintain equipment. Electrical energy used in these buildings is for lighting, heating and ventilation, overhead doors, and electric windows. The major reason for differences in their electrical usage appears to be in the operation of the heating and ventilating systems. Each building has exhaust fans which remove air from the ground floor of the building and vent to the exterior. In addition, numerous unit heaters located about 12 ft (3.6 m) above the floor are connected to individual thermostats. Ten thermostats were visually observed and eight were found set at a temperature of 90°F (17.8°C). Unit heaters were operating when the outside air temperature was 60°F (15.6°C) and the overhead doors to the maintenance bays were fully open.

Figures 8 and 9 show plots of winter electrical usage for Buildings 2492 and 2992, respectively. These curves show the high minimum consumption of Building 2492 and the higher maximums attributed to operational usage in Building 2992. Figure 8 shows the high minimum consumption (75 percent of total consumption for Building 2492) and the variation (36 to 71 kW) between minimum and maximum hourly demands. Figure 9 shows Building 2992's much lower (30 percent) minimum consumption and much larger variation (6 to 66 kW) caused by its operations and occupancy.

Figures 10 and 11, the summer monthly profiles for the two buildings, show a sharp drop in minimum demand. Building 2492's minimum demand went from 36 to 10 kW, and Building 2992's minimum demand went from 8 to 2 kW. Note that the decrease in minimum demand directly relates to the total consumption, which is also much lower during the summer months.

Table 19 shows data for Building 216, an administration building at Fort Belvoir. Although there are few data available for Building 216, indications are that it consumes, on the average, 0.0146 kWh/sq ft/day. This building shows a very small minimum hourly demand for summer months, and only a slight increase in demand in the winter months -- about 8 kW/hour/day. It appears that this building's minimum hourly demand is well within consumption ranges; the daily consumption profile shows that Building 216 follows the profile expected of an administrative building. The low minimum demand is caused by the type of heating system installed in the building; this system uses hot water radiation instead of forced air and, therefore, has a small electrical demand.

Table 20 shows data for Building 20, the officer's open mess facility at Fort Belvoir. Building 20 consumes, on the average, 0.051 kWh/sq ft/day. The monthly consumption data in Table 20 show substantial increases for the summer months (when AC is used). The data do not show any substantial, consistent trend in increases or decreases from 1976 to 1977 or 1977 to 1978. Building 20's minimum hourly demand in both

summer and winter is very high, i.e., 75 percent of the annual total consumption. This building is cooled by two 100-ton individual compressors, which causes summer electrical energy consumption to be substantially higher than winter consumption. This high summer demand is also reflected in the daily summer and daily winter seasonal consumption data.

Table 21 shows data for Building 1099, a dental clinic at Fort Belvoir. Building 1099 consumes about 0.044 kWh/sq ft/day. The monthly consumption data in Table 21 show that Building 1099 uses almost twice as much electrical energy during the summer cooling months as it uses during the winter heating months. This increase is also reflected in the seasonal consumption data, which show a difference in maximum weekday hourly demands between summer and winter operations of 50 percent. In this building, the AC system was left running on Saturdays and Sundays. The difference between the hourly minimum for summer weekends and weekdays is caused by the building user shutting down the AC during the night on weekdays, but failing to shutdown the AC on weekends; i.e., the weekday minimum is only half that of the weekend minimum. This building would be a candidate for clock-controlled HVAC.

Table 22 shows data from Building 2120, a theater at Fort Belvoir. Building 2120 consumes an average of 0.0296 kWh/sq ft/day. The monthly consumption data in Table 22 show considerable fluctuation between summer and winter consumption and from month to month, with no evidence of increases or decreases from one year to the next. The seasonal consumption data show a very reasonable minimum consumption for the summer considering a minimum operational status which includes security lighting, fire alarm, clocks, and safety lighting. However, the winter minimum consumption is 80 percent of the total daily consumption. The effects of occupancy within the building (i.e., lighting, projectors, and concessions), therefore, contribute only 20 percent to the total daily consumption during the winter months.

Table 23 shows data for Building 508, a bachelor officer's quarters at Fort Belvoir. Building 508 consumes, on the average, 0.0128 kWh/sq ft/day. This building consumes roughly twice as much electrical energy in the summer as it does in the winter. The data show that the AC is turned on about mid-June and off in mid-September. The summer minimum demand is about 70 percent of the daily total and the winter minimum demand is 58 percent of the daily total. Weekend consumption is slightly higher than the weekday consumption.

Table 24 shows data for Building 2111, a bachelor enlisted quarters at Fort Belvoir. Building 2111 consumes, on the average, 0.0135 kWh/sq ft/day. The monthly consumption data in Table 24 show an increase in electrical energy use during the winter months. This increase can be attributed to longer operation of fan coil units and extended hours of lighting during the winter. Since this building is cooled by chilled water from a central plant, no electrical cooling energy is being used besides the fan and pump energy. The building did not show any

substantial increases in electrical energy consumption between 1977 and 1978. Note that this building's winter and summer minimum hourly demand is equal -- 8 kW. This minimum demand, if extended for the entire year ($8 \times 24 \times 365$), would produce a total of 70,000 kWh vs an actual consumption of 95,000 kWh. The minimum demand is, therefore, 73 percent of the total annual consumption.

Table 25 shows data from Building 203, a bachelor enlisted quarters at Fort Belvoir. Building 203 consumes, on the average, 0.0107 kWh/sq ft/day. The monthly consumption data in Table 25 show that the highest electrical consumption occurs during the cooling months of July, August, and September, more than twice the consumption shown during the heating season. The hourly minimum of this building is 7 kW (cooling or heating), or 64 percent of Building 203's annual electrical energy consumption.

Table 26 shows data for Building 1200, an enlisted dining facility at Fort Belvoir. Building 1200 consumes, on the average, 0.026 kWh/sq ft/day. The monthly consumption data in Table 26 show a fairly consistent consumption of electrical energy throughout the summer and winter periods, even though the building has a 100-ton AC unit. The seasonal consumption data show that the weekend daily consumption is about 15 percent higher than the weekday consumption, and that the minimum hourly consumption of 20 kW is consistent both in the summer and the winter. If the 20 kW minimum hourly consumption is extended for 24 hours and 365 days a year, the minimum consumption in Building 1200 can be computed to be 72 percent of the total annual consumption.

Table 27 shows data for Building 1949, a motor pool at Fort Belvoir. Building 1949 consumes, on the average, 0.0125 kWh/sq ft/day. Since this building has no cooling, the monthly electrical energy consumption in the winter is higher than in the summer. Of interest is the winter minimum demand -- 5 kW for weekends (nonoperational) and only 3 kW for weekdays. There is no apparent reason for this, but it is suspected that the heating system is being manually controlled during the week, but not on weekends. The minimum demand for summer is extremely small -- 0.2 kW, which can be attributed to the water heater and security lighting.

Summary

A major portion of the electrical energy consumption of the buildings analyzed during this study occurs during nonduty or unoccupied hours. In many instances, annual unoccupied consumption contributes up to 75 percent of the total annual consumption of the facility. It appears from these data, then, that substantial emphasis should be placed on reducing minimum baseline electrical energy consumption. A reduction of this minimum baseline would provide savings every hour of the year, and should provide a corresponding reduction in peak maximum demands.

4 OPERATIONAL FINDINGS

Fort Belvoir

Electrical energy conservation at Fort Belvoir is a part of the Utility Energies Conservation program, which is under the Directorate of Facilities Engineering. Fort Belvoir's overall energy conservation program is supervised by the Directorate of Industrial Operations (DIO). The Energy Conservation Council (ECC) implements and coordinates this energy conservation program. ECC membership includes the DIO; the Director of Facilities Engineering; the U.S. Army Engineer School; the Division of Personnel and Community Facilities; Unit Commanders; and Tenant Activities. Unit/activity energy conservation officers are appointed for specific buildings and areas. Periodic surveys are conducted to identify potential conservation actions such as reducing the number of lights in hallways, supply rooms, warehouses, dining facilities, and to make sure equipment is turned off when not in use. Possible consolidation of functions to reduce the number of buildings being used is also considered.

The program to reduce electrical energy consumption at Fort Belvoir includes:

1. Reducing outdoor lighting not required for mission safety or security.
2. Reducing lighting at work stations, work areas, and nonworking areas to recommended footcandle levels.
3. Limiting or delaying the turn-on of AC systems, except for facilities such as medical, data processing, or laboratory buildings.
4. Changing working hours to permit early AC turn-off during peak cooling months.
5. Setting AC controls to a maximum cooling temperature of between 78 and 80°F (25.5 to 26.6°C).
6. Publishing electrical energy saving practices, tips, and encouraging participation in an energy conservation suggestion program.
7. Scheduling athletic events for daylight hours.

Fort Belvoir has activated two facilities over the past 3 years, including a flight-simulation building and a night-vision laboratory building. Other recent building modifications include installation of an AC system in the Defense Systems Management College and in the installation library. There have been no major deactivation of facilities in the past 3 years. Fort Belvoir's troop and civilian personnel population has decreased slightly since 1977.

There are currently four active energy conservation projects at Fort Belvoir:

1. A building delamping project to reduce lighting to recommended footcandle levels.
2. A project to replace street lighting to reduce the lighting levels from 2500 lumens to 1000 lumens.
3. A project to change street lighting in family housing areas from incandescent lamps to high-pressure sodium lamps.
4. A load shedding project which includes the use of timeclocks to reduce AC loads during the cooling season.

An installation-wide energy study to examine electrical energy use is also in progress. It is a phased study which will identify quick-fix conservation measures. The study is being conducted by a contractor under the supervision of the Baltimore District of the U.S. Army Corps of Engineers.

Table 28 shows the electrical energy consumption (by month) for FY77 to FY79 at Fort Belvoir. Major electrical consumers on the installation include the hospital, the research and development area (MERAD-COM), the Kingman Complex (Buildings 2992 and 2993), and family housing.

Fort Carson

Electrical energy conservation activities at Fort Carson are integrated into the installation's overall energy conservation program. An energy conservation office under the Deputy Installation Commander has staff responsibility for the program. An energy conservation board implements and coordinates energy conservation measures. Board membership includes: the DIO, the Directorate of Facilities Engineering, the Director of Personnel and Community Activities, and Unit Commanders. The board members appoint unit activity conservation officers who are responsible for assigned buildings and areas. They perform periodic surveys and inspections of their areas to identify measures for reducing consumption such as storage consolidation or lighting level reduction.

The program to reduce electrical energy consumption at Fort Carson includes:

1. Reducing the use of lights in offices and billets by performing lighting surveys to measure footcandle output.
2. Establishing a new schedule for turning exterior lights on and off to assure optimum use of daylight.

3. Limiting or delaying turn-on of AC systems, except for medical, data processing, and other areas requiring a controlled environment.

4. Setting AC controls at 78 to 80°F (25.5 to 26.6°C).

5. Publishing energy conserving suggestions to encourage installation-wide participation in the program.

6. Limiting the use of outdoor or decorative lighting except where safety or security is involved.

7. Scheduling athletic events for daylight hours.

New facilities activated at Fort Carson since 1977 include a dental clinic, a headquarters building, and several modular barracks buildings. No major facilities have been deactivated, but a continuing program to phase out old temporary buildings (e.g., barracks) as new facilities are completed is in effect. There has been no major change in the resident or nonresident population at Fort Carson since 1977.

There are currently three active electrical energy conservation projects at Fort Carson:

1. A delamping project for shops and offices (this project is continuing and is monitored through periodic building inspections).

2. A project to replace mercury vapor street and parking lot lights with high-pressure sodium lamps.

3. A project to correct power factors by installing capacitors and encouraging load shedding. Also, as a part of the installation energy conservation efforts, a baseline energy study is being conducted by a contractor under the supervision of the Omaha District of the U.S. Army Corps of Engineers. This study is expected to be completed in FY80. Table 29 shows the electrical energy consumption (by month) at Fort Carson from FY77 to FY79.

Discussion

Both Fort Belvoir and Fort Carson have established energy conservation programs that included electrical considerations in their development. The programs are similar and both have placed primary emphasis on reducing occupancy-related energy consumption. Both programs have implemented projects to reduce consumption, but it will not be possible to do a precise, quantitative evaluation of project results until they are completed and until there is widespread metering of buildings included in the programs. However, results to date from data gathered from buildings on both installations which were metered under the energy monitoring program do not indicate any across-the-board reductions which can be attributed to installation energy conservation efforts.

In addition, the total installation consumption data do not show reduction in electrical usage over a 3-year period (Tables 28 and 29).

General Trends Indicated by Representative Installation Analyses

Although Army installation energy conservation officers and Facility Engineering personnel feel confident that their energy conservation plans were working, many discrepancies within buildings and electrical energy waste were observed during visits conducted for this study. Some specific examples of such waste are:

1. Lights left on when lighting was not required (this included classrooms, mechanical rooms, hallways, and exterior lights burning during daytime hours).

2. Malfunctioning HVAC equipment; e.g., a compressor left on when there was no AC load, faulty dampers stuck in the open or closed position, fully opened outside air dampers when the temperature outside was very warm, dirty filters, fans operating in areas not being used and when the building was unoccupied, and many timeclocks that were installed but subsequently disconnected.

3. Exceptions to the AC turn-on policy for facilities such as officer's clubs, noncommissioned officer's clubs, hospitals, and dental facilities, practically all nonappropriated funds (NAF) activities, and many housing units. In addition, building temperatures during the cooling season were often lower than the required 78 to 80°F (25.5 to 26.6°C).

Onsite measurements were made at representative Army facilities by using recording ammeters for periods from 2 to 36 hours. Many of the discrepancies mentioned above were discovered during these measurements. For example, a recording ammeter was left on two AC units for 24 hours. One AC unit showed a continuous demand of 140 A -- at no time during the 24 hours did this particular unit turn off or cycle. A second AC unit in the same building cycled repeatedly during the 24 hours it was monitored. It was concluded that the first AC unit's controls were malfunctioning, since it was always operating in an unloaded condition and was not contributing to the AC load of the building. Another building (an enlisted dining facility) was continuously monitored to determine its AC consumption. It was found that its AC system operated continuously, even during periods when the building was unoccupied.

Summary

A large percentage of the total annual electricity consumption of buildings at Army installations seems to be caused by the magnitude of the minimum baseline consumption (lowest hourly demand/consumption). This minimum amount is being consumed for every hour of the year. A 1 kW reduction in the minimum demand in a building would save 8760 kWh/year, which would be equal to a 5 percent reduction in Army buildings such as those described in Tables 11 through 16. Therefore, substantial savings in electrical energy consumption can be achieved by reducing a building's minimum demand.

The present emphasis and control of electrical conservation policy and methods at Army installations requires additional attention. The minimum demand on an installation is caused by a variety of items including street and security lighting, housing, entertainment, and heating and cooling equipment. The minimum demand in many of the buildings can be attributed mainly to the heating and cooling system operation (fans, pumps, compressors) and is not directly related to occupancy requirements.

To date, the emphasis in Army installation energy conservation efforts has been primarily aimed at building occupants. However, data indicate that most of a building's electrical energy use is not directly related to building occupancy. Therefore, energy conservation programs which emphasize reducing building operational demands should be developed.

To help Facilities Engineers determine where the electricity is being used in buildings and to help develop a method to reduce this consumption, an inspection procedure was developed during this study. This inspection procedure is included in the appendix. It suggests a method of determining the major users of electrical energy in a building, how to inspect individual buildings, how to evaluate inspection results, and suggests a checklist to use during building inspections.

5 CONCLUSIONS

1. Seventy percent of the electrical energy used on the Army installations studied is being consumed on a continuous (baseline) basis; only 30 percent of the total energy consumption is caused by building occupancy and installation daily operations.

2. Up to 75 percent of a building's annual consumption is caused by its minimum hourly usage (demand). A large portion of this usage is directly attributed to HVAC system operation.

3. The most effective way to reduce electrical energy consumption on Army installations is to reduce the minimum hourly usage (demand) of individual installation buildings. This can be done by analyzing and optimizing HVAC system and building operation. For example, if the minimum hourly usage (demand) of a typical bachelor housing facility is reduced by 1 kW/hour, the facility's overall electrical energy consumption will decrease by 5 percent.

Table 1

Building Locations and Functions

Fort Belvoir
Building No.

203	Bachelor Enlisted Quarters (Barracks)
2111	Bachelor Enlisted Quarters (Modular Barracks)
508	Bachelor Officers Quarters (BOQ)
216	Administrative Building
20	Officer's Open Dining Facility
2120	Post Theater
1200	Enlisted Open Dining Facility
1949	Motor Pool
1099	Dental Clinic

Fort Carson
Building No.

811	Bachelor Enlisted Quarters w/Dining Facilities (Barracks)
1044	Bachelor Enlisted Quarters (Barracks)
1219	Bachelor Enlisted Quarters w/Dining Facilities (Barracks)
1951	Bachelor Enlisted Quarters (Modular Barracks)
7304	Bachelor Officers Quarters (BOQ)
1430	Administrative Building
1230	Recreation Center
7300	Officer's Open Dining Facility
1525	Commissary
2492	Maintenance Shop
2992	Maintenance Shop

Table 2

Monthly Feeder Electrical Consumption -- July 1976 through June 1977

	Feeder 1	Feeder 2	Feeder 3	Feeder 4	Feeder 5	Feeder 6	Feeder 7	Feeder 8	Total
JUL 76	789,500	459,600	496,300	940,000	837,100	369,400	348,500	665,000	4,905,400
AUG 76	736,700	465,600	489,300	936,800	809,400	373,300	654,600	454,100	4,919,800
SEP 76	684,800	478,400	496,200	876,800	745,000	411,600	603,100	549,900	4,845,800
OCT 76	716,800	523,600	518,100	852,300	709,600	439,400	602,300	630,200	4,992,300
NOV 76	723,200	552,600	545,800	822,200	662,100	470,100	610,500	653,000	5,039,500
DEC 76	779,300	558,600	612,400	851,100	658,600	473,200	622,600	686,600	5,242,400
JAN 77	805,100	466,400	568,600	839,500	679,400	506,100	659,100	743,500	5,267,700
FEB 77	736,700	389,700	488,500	700,100	599,000	431,300	573,100	635,200	4,562,600
MAR 77	746,100	537,000	523,200	721,600	534,000	455,700	611,200	675,100	4,803,900
APR 77	722,900	482,000	479,100	681,700	479,300	400,600	561,400	570,600	4,377,500
MAY 77	713,900	473,600	452,100	697,700	499,100	381,800	550,000	526,700	4,294,900
JUN 77	800,400	434,700	423,000	608,100	576,100	359,000	548,500	551,400	4,301,200

Table 3
Monthly Feeder Electrical Consumption -- July 1977 through June 1978

	Feeder 1	Feeder 2	Feeder 3	Feeder 4	Feeder 5	Feeder 6	Feeder 7	Feeder 8	Total
FY78									
JUL 77	818,600	509,200	338,200	303,000	628,200	356,600	582,500	579,900	4,116,200
AUG 77	--	--	--	--	--	--	--	--	--
SEP 77	712,000	451,700	--	--	532,400	319,100	485,660	550,100	--
OCT 77	693,300	--	454,600	--	491,100	136,700	345,600	585,000	--
NOV 77	704,900	580,800	131,700	1,030,700	505,100	489,500	675,600	649,900	4,776,200
DEC 77	695,400	590,200	443,300	758,000	584,100	508,000	715,400	665,500	4,959,900
JAN 78	709,100	570,100	554,700	831,100	555,800	579,800	732,400	791,900	5,324,900
FEB 78	632,900	533,200	471,300	668,700	464,300	485,800	648,700	684,800	4,689,700
MAR 78	696,500	590,800	493,800	699,900	508,700	485,100	680,000	700,400	4,855,200
APR 78	668,400	640,600	414,100	660,100	474,700	406,000	620,400	580,400	4,464,700
MAY 78	692,900	569,300	414,100	723,200	509,600	--	--	--	--
JUN 78	781,900	499,400	387,000	793,200	587,400	284,653	--	--	--

Table 4

Daily Feeder Electrical Consumption

	Feeder 1	Feeder 2	Feeder 3	Feeder 4	Feeder 5	Feeder 6	Feeder 7	Feeder 8
<u>Winter</u>								
15 JAN 78 (Sunday)								
Consumption	17,980	16,950	18,670	26,740	13,230	15,770	23,150	23,930
MAX demand	899	1,029	1,140	1,248	720	1,025	1,046	1,177
MIN demand	629	480	449	1,019	425	487	821	763
% of daily	84	68	58	91	77	74	85	77
17 JAN 78 (Tuesday)								
Consumption	25,380	18,950	23,960	32,520	17,660	18,960	24,350	24,470
MAX demand	1,287	1,044	1,370	1,569	1,022	1,233	1,140	1,223
MIN demand	684	518	666	1,072	438	497	870	689
% of daily	65	66	67	79	60	63	86	68
<u>Summer</u>								
11 JUN 78 (Sunday)								
Consumption	20,950	15,430	7,780	22,900	15,450	8,800	--	--
MAX demand	1,002	1,060	567	1,130	809	531	--	--
MIN demand	672	422	234	769	514	265	--	--
% of daily	77	66	72	81	80	72	--	--
13 JUN 78 (Tuesday)								
Consumption	29,750	18,460	15,560	28,540	21,400	12,680	--	--
MAX demand	1,538	1,076	1,011	1,388	1,235	774	--	--
MIN demand	840	556	348	973	527	320	--	--
% of daily	68	72	54	82	59	61	--	--

Table 5

Fort Carson Weather Parameters

<u>Date</u>	MAX Temperature °F(°C)	MIN Temperature °F(°C)	Average Temperature °F(°C)	<u>HDD</u>	<u>CDD</u>
15 Jan 78	36 (2.2)	16 (-8.8)	26 (-3.3)	39	0
17 Jan 78	42 (5.5)	3 (-16.1)	23 (-5)	42	0
11 Jun 78	76 (24.4)	56 (12.3)	66 (18.8)	--	1
13 Jun 78	88 (31.1)	51 (10.5)	70 (21.1)	--	5

Table 6

Weather Parameters (Daily Data)

Fort Carson

<u>Date</u>	MAX Temperature °F(°C)	MIN Temperature °F(°C)	Average Temperature °F(°C)	<u>HDD</u>	<u>CDD</u>
14 Jan 78	35 (1.6)	14 (-10)	25 (-3.8)	40	0
15 Jan 78	36 (2.2)	16 (-8.8)	26 (-3.3)	39	0
17 Jan 78	42 (5.5)	3 (-16.1)	23 (-5)	42	0
18 Jan 78	31 (-0.5)	16 (-8.8)	24 (-4.4)	41	0
17 Jun 78	80 (26.6)	56 (13.3)	68 (20)	0	3
18 Jun 78	74 (23.3)	55 (12.7)	65 (18.3)	0	0
20 Jun 78	70 (21.1)	49 (9.4)	60 (15.5)	5	0
21 Jun 78	89 (31.6)	57 (13.8)	73 (22.7)	0	8

Fort Belvoir

14 Jan 78	37 (2.7)	31 (-0.5)	34 (0.1)	31	0
15 Jan 78	33 (0.5)	24 (-4.4)	29 (-1.6)	36	0
17 Jan 78	38 (3.3)	31 (-0.5)	35 (1.6)	30	0
18 Jan 78	40 (4.4)	29 (-1.6)	35 (1.6)	30	0
17 Jun 78	78 (25.5)	70 (21.1)	74 (23.3)	0	9
18 Jun 78	94 (34.4)	71 (21.6)	83 (28.3)	0	18
20 Jun 78	88 (31.1)	69 (20.5)	79 (26.1)	0	14
21 Jun 78	88 (31.1)	70 (21.1)	79 (26.1)	0	14

Table 7
Heating and Cooling Degree Days

	Fort Carson		Fort Belvoir	
	<u>HDD</u>	<u>CDD</u>	<u>HDD</u>	<u>CDD</u>
JUL 76	0	227	0	424
AUG	11	114	0	370
SEP	191	28	11	179
OCT	503	0	306	15
NOV	859	0	652	0
DEC	988	0	907	0
JAN 77	1181	0	1221	0
FEB	837	0	729	0
MAR	858	0	389	10
APR	494	0	188	49
MAY	192	0	32	177
JUN	5	103	3	289
JUL	2	204	0	496
AUG	22	142	0	434
SEP	73	49	1	274
OCT	413	0	196	18
NOV	784	0	406	15
DEC	938	0	829	0
JAN 78	1231	0	1001	0
FEB	1036	0	933	0
MAR	741	0	633	0
APR	479	0	219	10
MAY	386	4	86	117
JUN	98	143	0	358

Table 8

Building 1430 -- Fort Carson

Building Function: Administration Location: Fort Carson Year Built: 1957
 Building Number: 1430 Floor Area: 41,180 sq ft

BUILDING EQUIPMENT		MONTHLY CONSUMPTION (kWh)					
Type/Description	Approximate Connected Load		1976-1977	1977-1978			
Lighting		Jul	--	43,900			
Incandescent	7.9	Aug	--	40,940			
Fluorescent	43.8	Sep	--	36,880			
HVAC		Oct	--	36,330			
Air conditioning	19.0	Nov	38,720	39,100			
Pumps	1.0	Dec	40,520	39,560			
Fans	9.9	Jan	40,330	37,720			
Other Equipment		Feb	36,890	--			
Typewriters	8.6	Mar	39,550	37,530			
Copiers	13.8	Apr	37,580	39,340			
Word processing	1.8	May	36,120	41,430			
Telecommunications	50.0	Jun	43,710	43,840			
Vending	3.1						
Audio visual	5.3						
Miscellaneous	12.2						
		SEASONAL CONSUMPTION (kWh)					
		Summer		Winter			
		Daily	Hourly MIN	Hourly MAX	Daily	Hourly MIN	Hourly MAX
17 Jun 78/14 Jan 78 (Sat)	1040		41	47	905	34	41
18 Jun 78/15 Jan 78 (Sun)	1007		38	46	841	33	38
20 Jun 78/17 Jan 78 (Tues)	1671		41	101	1522	31	91
21 Jun 78/18 Jan 78 (Wed)	1688		38	108	1551	32	95

Comments:

Administrative Building--office occupancy for typical work week.
 Time range approximately 7:30 AM to 4:15 PM. Estimated 50 hours/week
 occupancy including janitorial.

Lighting--25% on corridors; 75% to 100% on offices.

Cooling accomplished by individual window units (12 kW) and central
 unit for selected spaces.

Table 9
Building 7300 -- Fort Carson

Building Function: Officer's open mess Location: Fort Carson Year Built:
Building Number: 7300 Floor Area: 19,089 sq ft

BUILDING EQUIPMENT			MONTHLY CONSUMPTION (kWh)		
Type/Description	Approximate Connected Load		1976-1977	1977-1978	
Lights			Jul	--	56,940
Incandescent	4.0		Aug	--	53,130
Fluorescent	14.7		Sep	--	42,500
HVAC			Oct	--	38,640
Refrigeration (AC)	48		Nov	--	33,160
Fans	18.5		Dec	34,690	34,760
Other Equipment			Jan	39,750	32,590
Refrigeration	20.5		Feb	35,770	33,580
Food Preparation	5.0		Mar	40,580	35,740
Miscellaneous	4.5		Apr	39,620	36,740
			May	42,190	40,210
			Jun	57,000	52,070

SEASONAL CONSUMPTION (kWh)							
			Summer			Winter	
			Daily	Hourly MIN	Hourly MAX	Daily	Hourly MIN
17 Jun 78/14 Jan 78 (Sat)	1691	42	90	1063	25	61	
18 Jun 78/15 Jan 78 (Sun)	1267	30	80	723	18	56	
20 Jun 78/17 Jan 78 (Tues)	1599	37	93	1084	22	75	
21 Jun 78/18 Jan 78 (Wed)	1733	39	102	1045	22	71	

Comments:

Officers open dining facility--occupancy generally in evening from
5 PM to 12 PM.
Cooling is accomplished by roof-mounted AC units.

Table 10

Building 1525 -- Fort Carson

Building Function: Commissary Location: Fort Carson Year Built: 1974
 Building Number: 1525 Floor Area: 81,455 sq ft

BUILDING EQUIPMENT			MONTHLY CONSUMPTION (kWh)			
Type/Description	Approximate Connected Load		1976-1977	1977-1978		
Lights		Jul	--	260,840		
Fluorescent	37.0	Aug	--	251,040		
Incandescent	10.2	Sep	--	227,130		
HVAC		Oct	--	202,810		
Air handling units	32.4	Nov	232,250	162,960		
Fans	38.5	Dec	236,130	216,360		
Pumps	5.1	Jan	240,480	226,180		
Unit heaters	2.9	Feb	219,720	205,620		
Refrigeration	138.8	Mar	234,360	233,920		
Produce & meat prep- aration	26.9	Apr	237,910	225,170		
Other Equipment		May	234,360	238,220		
Battery chargers	8.0	Jun	260,770	265,610		
Cash registers	2.3					
Miscellaneous	3.5					
			SEASONAL CONSUMPTION (kWh)			
			Summer		Winter	
			Hourly	Hourly	Hourly	
			Daily	MIN	MAX	
			Daily	MIN	MAX	
17 Jun 78/14 Jan 78 (Sat)	8780	221	495	7780	222	385
18 Jun 78/15 Jan 78 (Sun)	7010	219	362	5620	220	302
20 Jun 78/17 Jan 78 (Tues)	9200	247	455	7910	219	296
21 Jun 78/18 Jan 78 (Wed)	9580	256	492	7910	227	390

Comments:

Commissary Hours of Operation: 9 AM to 6 PM Weekdays; 9 AM to 5 PM Saturdays.

Night crews working use about 45% lighting (fluorescent).

Produce and meat preparation = 8 hours/day 5 days/week.

Cooling load includes both AC (about 100 ton) and process refrigeration.

Table 11

Building 7304 -- Fort Carson

Building Function: BOQ Location: Fort Carson Year Built: 1970
 Building Number: 7304 Floor Area: 37,100 sq ft

BUILDING EQUIPMENT		MONTHLY CONSUMPTION (kWh)		
Type/Description	Approximate Connected Load		1976-1977	1977-1978
Lights		Jul	12,887	8,588
Incandescent	2.1	Aug	13,232	NA
Fluorescent	4.4	Sep	13,476	13,471
Outside	0.70	Oct	15,211	NA
HVAC		Nov	16,051	15,795
Pumps	2.8	Dec	16,315	15,677
Fans	12.0	Jan	18,511	17,936
Other Equipment		Feb	16,455	14,998
Laundry	29.6	Mar	17,929	16,619
Refrigeration	7.6	Apr	16,418	16,171
Miscellaneous	0.6	May	15,578	16,484
		Jun	13,533	14,488

SEASONAL CONSUMPTION (kWh)								
			Summer			Winter		
			Daily	Hourly MIN	Hourly MAX	Daily	Hourly MIN	Hourly MAX
17 Jun 78/14 Jan 78 (Sat)			486	16	26	647	20	36
18 Jun 78/15 Jan 78 (Sun)			516	15	29	555	18	33
20 Jun 78/17 Jan 78 (Tues)			469	14	31	670	17	46
21 Jun 78/18 Jan 78 (Wed)			456	14	25	585	15	40

Comments:

BOQ facility peak occupancy late early and early morning from about 6 PM to 6 AM.

BOQ capacity -- 77 rooms.

Rooms contain individual exhaust fans.

Table 12

Building 1953 -- Fort Carson

Building Function: BEQ Location: Fort Carson Year Built: 1974
 Building Number: 1953 Floor Area: 21,280 sq ft

BUILDING EQUIPMENT		MONTHLY CONSUMPTION (kWh)	
Type/Description	Approximate Connected Load	1976-1977	1977-1978
Lights		Jul --	9,597
Incandescent	9.8	Aug --	10,577
Fluorescent	4.0	Sep --	9,466
HVAC		Oct --	11,756
Pumps	4.5	Nov 12,274	11,734
Fans	11.3	Dec 12,456	12,611
Other Equipment		Jan 13,941	13,509
Laundry	15.1	Feb 11,881	12,796
Miscellaneous	0.4	Mar 12,995	13,320
		Apr 11,126	11,580
		May 10,745	10,872
		Jun 10,358	11,077

		SEASONAL CONSUMPTION (kWh)					
		Summer			Winter		
		Daily	Hourly MIN	Hourly MAX	Daily	Hourly MIN	Hourly MAX
17 Jun 78/14 Jan 78 (Sat)		361	12	19	423	14	25
18 Jun 78/15 Jan 78 (Sun)		398	12	21	463	14	25
20 Jun 78/17 Jan 78 (Tues)		356	9	23	397	14	23
21 Jun 78/18 Jan 78 (Wed)		381	12	22	421	13	27

Comments:

Barracks facility peak occupancy from 6 PM to 6 AM.
 Cooling is accomplished by chilled water from central plant. Fan coil units in individual rooms, corridors and lounges.

Table 13

Building 811 -- Fort Carson

Building Function: BEQ w/dining Location: Fort Carson Year Built: 1956
 Building Number: 811 Floor Area: 40,427 sq ft

BUILDING EQUIPMENT		MONTHLY CONSUMPTION (kWh)		
Type/Description	Approximate Connected Load		1976-1977	1977-1978
Lighting		Jul	--	22,060
Incandescent	6.3	Aug	--	22,170
Fluorescent	12.3	Sep	--	21,420
HVAC		Oct	--	18,470
Pumps	14.3	Nov	22,030	18,780
Fans	7.5	Dec	19,720	16,310
Mess Facility		Jan	21,630	18,430
Refrigeration	10.0	Feb	19,370	14,530
Food preparation	13.3	Mar	18,530	15,130
Barracks Facility		Apr	20,210	11,470
Laundry	26.8	May	18,370	--
Miscellaneous	4.4	Jun	19,390	--

SEASONAL CONSUMPTION (kWh)						
Summer			Winter			
	Daily	Hourly MIN	Hourly MAX	Daily	Hourly MIN	Hourly MAX
17 Jun 78/14 Jan 78 (Sat)	702	20	36	656	20	32
18 Jun 78/15 Jan 78 (Sun)	635	22	31	645	18	32
20 Jun 78/17 Jan 78 (Tues)	888	28	43	615	18	31
21 Jun 78/18 Jan 78 (Wed)	881	27	43	645	17	33

Comments:

Barracks facility peak occupancy essentially from 6 PM to 6 AM.
 Dining facility -- 3 meals/day (Monday through Friday).
 Barracks capacity -- about 178 personnel.
 Cooling accomplished by chilled water from central plant.

Table 14

Building 1219 -- Fort Carson

Building Function: BEQ Location: Fort Carson Year Built: 1958
 Building Number: 1219 Floor Area: 51,760 sq ft

BUILDING EQUIPMENT		MONTHLY CONSUMPTION (kwh)	
Type/Description	Approximate Connected Load	1976-1977	1977-1978
Lighting		Jul --	14,090
Incandescent	19.5	Aug --	15,190
Fluorescent	6.5	Sep --	14,280
HVAC		Oct --	15,210
Pumps	9.3	Nov 17,160	16,060
Fans	4.7	Dec 14,410	14,420
Mess Facility		Jan 17,470	15,750
Refrigeration	6.1	Feb 15,070	13,640
Food Preparation	12.0	Mar 15,490	14,720
Barracks Facility		Apr 14,890	13,630
Laundry	16.5	May 14,440	14,510
Miscellaneous	4.1	Jun 14,760	13,530

		SEASONAL CONSUMPTION (kwh)					
		Summer			Winter		
		Daily	Hourly MIN	Hourly MAX	Daily	Hourly MIN	Hourly MAX
17 Jun 78/14 Jan 78 (Sat)		297	10	16	411	15	21
18 Jun 78/15 Jan 78 (Sun)		309	11	16	440	14	23
20 Jun 78/17 Jan 78 (Tues)		541	17	28	570	13	31
21 Jun 78/18 Jan 78 (Wed)		492	12	28	570	16	31

Comments:

Barracks facility peak occupancy essentially from 6 PM to 6 AM.
 Dining facility -- 3 meals/day (Monday through Friday).

Table 15

Building 1971 -- Fort Carson

Building Function: BEQ Location: Fort Carson Year Built: 1971
 Building Number: 1044 Floor Area: 42,683 sq ft

BUILDING EQUIPMENT		MONTHLY CONSUMPTION (kWh)	
Type/Description	Approximate Connected Load	1976-1977	1977-1978
Lighting		Jul 25,080	20,770
Incandescent	0.9	Aug 28,150	11,030
Fluorescent	13.2	Sep 21,170	10,630
HVAC		Oct 15,460	11,760
Pumps	7.0	Nov 15,890	11,730
Fans	13.0	Dec 14,040	11,010
Air Conditioning	38.2	Jan 12,680	11,620
Other Equipment		Feb 11,250	9,920
Laundry	30.0	Mar 11,410	10,550
Miscellaneous	4.6	Apr 11,420	10,590
		May 10,840	10,760
		Jun 14,360	14,690

SEASONAL CONSUMPTION (kWh)										
					Summer			Winter		
					Daily	Hourly MIN	Hourly MAX	Daily	Hourly MIN	Hourly MAX
17 Jun 78/14 Jan 78 (Sat)					535	18	28	356	10	20
18 Jun 78/15 Jan 78 (Sun)					437	10	28	357	8	21
20 Jun 78/17 Jan 78 (Tues)					472	8	30	383	10	31
21 Jun 78/18 Jan 78 (Wed)					393	11	31	312	7	18

Comments:

Barracks facility peak occupancy from 6 PM to 6 AM.
 No dining facilities.
 Barracks capacity -- about 217 personnel.
 Cooling is supplied by central plant.

Table 16

Building 1230 -- Fort Carson

Building Function: Recreation center Location: Fort Carson Year Built: 1959
 Building Number: 1230 Floor Area: 26,732 sq ft

BUILDING EQUIPMENT		MONTHLY CONSUMPTION (kWh)		
Type/Description	Approximate Connected Load		1976-1977	1977-1978
Lights		Jul	--	19,160
Incandescent	9.1	Aug	--	21,470
Fluorescent	12.8	Sep	--	16,210
HVAC		Oct	--	--
Fans	16.4	Nov	11,540	10,320
Pumps	3.1	Dec	11,730	11,560
Other Equipment		Jan	12,030	9,970
Stage lighting	15.0	Feb	11,060	--
Office	2.0	Mar	10,730	10,490
Vending	2.7	Apr	9,440	9,920
Miscellaneous	4.7	May	8,420	10,520
		Jun	16,410	--

SEASONAL CONSUMPTION (kWh)								
			Summer			Winter		
			Daily	Hourly MIN	Hourly MAX	Daily	Hourly MIN	Hourly MAX
17 Jun 78/14 Jan 78 (Sat)	377	9	28	303	7	23		
18 Jun 78/15 Jan 78 (Sun)	334	9	26	313	7	28		
20 Jun 78/17 Jan 78 (Tues)	354	10	24	356	9	25		
21 Jun 78/18 Jan 78 (Wed)	370	10	23	369	9	28		

Comments:

Building is used as recreational center from 5:30 PM to 10:00 PM
 Monday through Thursday and 1 PM to 10 PM Saturday and Sunday. Building
 open for regular staff use 7 AM to 10 PM (daily).

Table 17

Building 2492 -- Fort Carson

Building Function: Maintenance Location: Fort Carson Year Built: 1966
 Building Number: 2492 Floor Area: 21,060 sq ft

BUILDING EQUIPMENT			MONTHLY CONSUMPTION (kwh)	
Type/Description	Approximate Connected Load		1976-1977	1977-1978
Lighting		Jul	10,430	14,920
Incandescent	6.3	Aug	8,620	15,550
Fluorescent	17.9	Sep	16,830	18,520
Outside	3.9	Oct	22,270	23,720
HVAC		Nov	26,030	25,850
Units heaters	13.2	Dec	28,170	28,910
Exhaust fans	2.2	Jan	32,160	34,510
Other		Feb	24,030	30,640
Door motors	6.1	Mar	24,010	28,850
Air compressor	12.2	Apr	19,680	23,150
Miscellaneous	2.4	May	18,120	19,230
		Jun	14,770	18,120

SEASONAL CONSUMPTION (kwh)								
			Summer			Winter		
			Daily	Hourly MIN	Hourly MAX	Daily	Hourly MIN	Hourly MAX
17 Jun 78/14 Jan 78 (Sat)			346	10	24	1101	42	53
18 Jun 78/15 Jan 78 (Sun)			368	9	24	1065	43	46
20 Jun 78/17 Jan 78 (Tues)			727	19	43	1209	42	61
21 Jun 78/18 Jan 78 (Wed)			694	21	35	1360	44	70

Comments:

Motor pool hours of operation -- 7:30 AM to 4:30 PM, 5 days/week.
 Intermittent operation -- motor pool shutdown if units are out in
 field, etc.
 Equipment and usage similar for Buildings 2492 and 2992.
 Portable generators used for welding equipment.

Table 18

Building 2992 -- Fort Carson

Building Function: Maintenance Location: Fort Carson Year Built: 1966
 Building Number: 2992 Floor Area: 21,060 sq ft

BUILDING EQUIPMENT		MONTHLY CONSUMPTION (kWh)		
Type/Description	Approximate Connected Load		1976-1977	1977-1978
Lighting		Jul	14,910	10,022
Incandescent	6.3	Aug	13,730	--
Fluorescent	17.9	Sep	17,010	--
Outside	3.9	Oct	20,990	--
HVAC		Nov	21,160	14,990
Units heaters	13.2	Dec	22,990	19,010
Exhaust fans	2.2	Jan	21,360	19,890
Other		Feb	21,420	17,600
Door Motors	6.1	Mar	24,050	15,890
Air compressor	12.2	Apr	20,250	15,390
Miscellaneous	2.4	May	11,423	14,900
		Jun	6,760	11,410

		SEASONAL CONSUMPTION (kWh)					
		Summer			Winter		
		Daily	Hourly MIN	Hourly MAX	Daily	Hourly MIN	Hourly MAX
17 Jun 78/14 Jan 78 (Sat)		171	3	15	418	16	19
18 Jun 78/15 Jan 78 (Sun)		207	3	15	414	15	18
20 Jun 78/17 Jan 78 (Tues)		405	5	30	872	26	49
21 Jun 78/18 Jan 78 (Wed)		360	6	31	937	30	50

Comments:

Motor pool hours of operation -- 7:30 AM to 4:30 PM, 5 days/week.
 Intermittent operation -- motor pool shutdown if units are out in field, etc.
 Equipment and usage similar for Buildings 2492 and 2992.
 Portable generators used for welding equipment.

Table 19

Building 216 -- Fort Belvoir

Building Function: Administration Location: Fort Belvoir Year Built: 1932
 Building Number: 216 Floor Area: 23,513 sq ft

BUILDING EQUIPMENT		MONTHLY CONSUMPTION (kwh)		
Type/Description	Approximate Connected Load		1976-1977	1977-1978
Lighting		Jul	NA	--
Incandescent	0.2	Aug	NA	--
Fluorescent	34.0	Sep	NA	--
HVAC		Oct	NA	--
Refrigeration	16.5	Nov	NA	10,480
Fans	0.7	Dec	NA	10,470
Pumps	6.7	Jan	NA	10,890
Other Equipment		Feb	NA	9,920
Copier	2.9	Mar	NA	12,120
Miscellaneous	2.4	Apr	NA	9,530
		May	NA	9,560
		Jun	NA	--

SEASONAL CONSUMPTION (kwh)								
			Summer			Winter		
			Daily	Hourly MIN	Hourly MAX	Daily	Hourly MIN	Hourly MAX
17 Jun 78/14 Jan 78 (Sat)			66	2.4	3	245	7	26
18 Jun 78/15 Jan 78 (Sun)			68	3.0	4	188	7	9
20 Jun 78/17 Jan 78 (Tues)			388	3	37	482	8	44
21 Jun 78/18 Jan 78 (Wed)			380	3	35	457	8	42

Comments:

Administrative building typical hours operations 7:30 AM to 4:15 PM (Monday through Friday).

Individual offices cooled with window air conditioning units (about 10 kW). Central unit cools selected areas such as conference room (8 ton).

Table 20

Building 20 -- Fort Belvoir

Building Function: Officer's open mess Location: Fort Belvoir Year Built: 1954
 Building Number: 20 Floor Area: 66,972 sq ft

BUILDING EQUIPMENT			MONTHLY CONSUMPTION (kwh)			
Type/Description	Approximate Connected Load		1976-1977	1977-1978		
Lighting		Jul	--	159,220		
Incandescent	66.4	Aug	--	162,480		
Fluorescent	19.3	Sep	126,240	135,410		
HVAC		Oct	104,680	90,870		
Refrigeration (AC)	145	Nov	89,280	86,440		
Fans	66.5	Dec	--	90,790		
Pumps	20.7	Jan	88,680	84,190		
Heaters	11.6	Feb	72,490	68,990		
Miscellaneous	9.4	Mar	75,450	73,460		
Other Equipment		Apr	82,990	66,820		
Refrigeration	72.1	May	109,010	91,030		
Food preparation	13.9	Jun	117,790	128,230		
Elevators	26.7					
Pool	15.7					
Miscellaneous	16.5					
			SEASONAL CONSUMPTION (kwh)			
			Summer		Winter	
			Daily	Hourly MIN	Daily	Hourly MIN
				Hourly MAX		Hourly MAX
17 Jun 78/14 Jan 78 (Sat)	4527	137	241	2719	96	139
18 Jun 78/15 Jan 78 (Sun)	4739	143	232	2590	96	121
20 Jun 78/17 Jan 78 (Tues)	4389	118	247	2819	93	152
21 Jun 78/18 Jan 78 (Wed)	4469	123	250	2948	93	149

Comments:

Officers open dining facility--occupancy generally in evening from 5 to 12 PM.

Guest facilities occupancy essentially late evening to early morning from 6 PM to 6 AM.

Cooling accomplished with two 100-ton units. Quarters are cooled with individual window units (about 23 kW).

Table 21

Building 1099 -- Fort Belvoir

Building Function: Dental clinic Location: Fort Belvoir Year Built: 1970
 Building Number: 1099 Floor Area: 14,188 sq ft

BUILDING EQUIPMENT			MONTHLY CONSUMPTION (kWh)			
Type/Description	Approximate Connected Load		1976-1977	1977-1978		
Lighting			Jul	--	26,080	
Incandescent	3.8		Aug	--	29,470	
Fluorescent	3.3		Sep	12,930	28,660	
HVAC			Oct	15,800	13,500	
Refrigeration (AC)	31.6		Nov	14,400	14,220	
Fans	12.3		Dec	13,750	14,210	
Pumps	3.6		Jan	13,540	13,690	
Other Equipment			Feb	12,660	13,930	
Compressors	12.2		Mar	13,910	16,840	
Pumps (vacuum)	12.4		Apr	11,930	14,440	
Prosthetics (29 rooms)	56.7		May	18,970	14,990	
X-ray	2.1		Jun	21,760	27,060	
Sterilization	7.4					
Lab	13.3					
Miscellaneous	13.0					
			SEASONAL CONSUMPTION (kWh)			
			Summer		Winter	
			Hourly	Hourly	Hourly	Hourly
			Daily	MIN	Daily	MIN
				MAX		MAX
17 Jun 78/14 Jan 78 (Sat)	670		19	34	207	8
18 Jun 78/15 Jan 78 (Sun)	760		21	40	207	8
20 Jun 78/17 Jan 78 (Tues)	933		10	65	506	8
21 Jun 78/18 Jan 78 (Wed)	1009		10	65	501	8

Comments:

Dental Clinic hours of operation -- 7:30 AM to 4:00 PM (Monday through Friday).

Cooling accomplished with 50-ton AC unit.

Table 22

Building 2120 -- Fort Belvoir

Building Function: Theatre Location: Fort Belvoir Year Built:
 Building Number: 2120 Floor Area: 10,650 sq ft

BUILDING EQUIPMENT			MONTHLY CONSUMPTION (kWh)	
Type/Description	Approximate Connected Load		1976-1977	1977-1978
Lighting		Jul	--	21,310
Incandescent	12.2	Aug	--	13,910
Fluorescent	0.9	Sep	--	8,460
HVAC		Oct	7,150	6,120
Refrigeration (AC)	18.0	Nov	7,425	9,570
Fans	11.5	Dec	--	9,440
Pumps	2.3	Jan	10,235	9,520
Other Equipment		Feb	7,650	9,470
Projector	4.0	Mar	5,980	9,760
Hand dryers	8.8	Apr	--	8,860
Miscellaneous	5.8	May	5,980	3,160
		Jun	10,033	5,460

SEASONAL CONSUMPTION (kWh)								
			Summer			Winter		
			Daily	Hourly MIN	Hourly MAX	Daily	Hourly MIN	Hourly MAX
17 Jun 78/14 Jan 78 (Sat)	94	2	9	320	11	18		
18 Jun 78/15 Jan 78 (Sun)	122	2	10	316	11	17		
20 Jun 78/17 Jan 78 (Tues)	434	2	47	310	11	17		
21 Jun 78/18 Jan 78 (Wed)	284	2	39	--	--	--		

Comments:

Theater facility involves evening occupancy from 6 to 12 PM.
 Cooling accomplished by two 15-ton AC.

Table 23

Building 508 -- Fort Belvoir

Building Function: B0Q Location: Fort Belvoir Year Built: 1969
 Building Number: 508 Floor Area: 18,360 sq ft

BUILDING EQUIPMENT			MONTHLY CONSUMPTION (kwh)					
Type/Description	Approximate Connected Load		1976-1977	1977-1978				
Lights		Jul	--	14,250				
Incandescent	18.6	Aug	--	12,490				
Fluorescent	3.4	Sep	11,620	8,830				
HVAC		Oct	8,930	4,400				
Refrigeration	9.7	Nov	8,910	5,000				
Pumps	4.0	Dec	8,610	5,320				
Fans	8.7	Jan	7,980	6,110				
Other Equipment		Feb	6,370	5,590				
Refrigeration	30.2	Mar	6,410	5,710				
Miscellaneous	3.4	Apr	4,170	5,860				
		May	4,200	4,590				
		Jun	9,080	7,480				
SEASONAL CONSUMPTION (kwh)								
			Summer		Winter			
			Daily	Hourly MIN	Hourly MAX	Daily	Hourly MIN	Hourly MAX
17 Jun 78/14 Jan 78 (Sat)	311	10	17	188	5	11		
18 Jun 78/15 Jan 78 (Sun)	415	9	32	190	4	12		
20 Jun 78/17 Jan 78 (Tues)	341	10	18	169	4	13		
21 Jun 78/18 Jan 78 (Wed)	330	9	14	149	4	11		

Comments:

Bachelor officer's quarters facility peak occupancy from 6 PM to 6 AM.
 Capacity -- 42 personnel.
 Cooling is accomplished with a 20-ton AC unit.

Table 24

Building 211 -- Fort Belvoir

Building Function: BEO Location: Fort Belvoir Year Built: 1975
 Building Number: 2111 Floor Area: 19,320 sq ft

BUILDING EQUIPMENT		MONTHLY CONSUMPTION (kwh)	
Type/Description	Approximate Connected Load	1976-1977	1977-1978
Lights		Jul --	6,880
Incandescent	14.4	Aug --	6,260
Fluorescent	1.4	Sep 4,680	7,750
HVAC		Oct 5,810	8,130
Pumps	7.6	Nov 6,770	8,460
Fans	12.6	Dec 7,380	9,020
Other Equipment		Jan 7,690	9,560
Laundry	24.6	Feb 7,220	8,530
Refrigeration	3.8	Mar 8,240	8,840
Miscellaneous	3.3	Apr 6,910	8,150
		May 6,330	6,780
		Jun 7,010	7,140

		SEASONAL CONSUMPTION (kwh)					
		Summer			Winter		
		Daily	Hourly MIN	Hourly MAX	Daily	Hourly MIN	Hourly MAX
17 Jun 78/14 Jan 78 (Sat)	247	8	14	312	8	19	
18 Jun 78/15 Jan 78 (Sun)	290	8	20	325	8	20	
20 Jun 78/17 Jan 78 (Tues)	250	8	18	311	8	21	
21 Jun 78/18 Jan 78 (Wed)	228	6	16	274	8	21	

Comments:

Enlisted barracks facility peak occupancy from 6 PM to 6 AM.
 Barracks capacity -- 132 personnel
 Cooling accomplished by fan coil units with chilled water from a central plant.

Table 25

Building 1928 -- Fort Belvoir

Building Function: BEQ Location: Fort Belvoir Year Built: 1928
 Building Number: 203 Floor Area: 24,331 sq ft

BUILDING EQUIPMENT		MONTHLY CONSUMPTION (kWh)		
Type/Description	Approximate Connected Load		1976-1977	1977-1978
Lighting		Jul	--	14,760
Incandescent	10.9	Aug	--	14,650
Fluorescent	15.0	Sep	6,780	11,310
HVAC		Oct	6,980	6,920
Refrigeration	21.0	Nov	7,400	6,030
Miscellaneous	1.9	Dec	7,850	5,550
Other		Jan	8,680	6,930
Laundry	14.8	Feb	7,460	7,250
Miscellaneous	3.5	Mar	8,080	6,900
		Apr	6,800	4,620
		May	7,090	3,820
		Jun	8,510	6,610

SEASONAL CONSUMPTION (kWh)								
			Summer			Winter		
			Daily	Hourly MIN	Hourly MAX	Daily	Hourly MIN	Hourly MAX
17 Jun 78/14 Jan 78 (Sat)	199	7	11	244	7	13		
18 Jun 78/15 Jan 78 (Sun)	187	6	10	235	7	12		
20 Jun 78/17 Jan 78 (Tues)	333	7	24	241	7	15		
21 Jun 78/18 Jan 78 (Wed)	392	5	21	231	7	14		

Comments:

Barracks facility peak occupancy essentially from 6 AM to 6 PM.
 Barracks capacity -- 68 personnel.
 Cooling accomplished with a 40-ton AC unit.

Table 26

Building 1200 -- Fort Belvoir

Building Function: Enlisted dining Location: Fort Belvoir Year Built: 1965
 Building Number: 1200 Floor Area: 24,045 sq ft

BUILDING EQUIPMENT				
<u>Type/Description</u>	<u>Approximate Connected Load</u>		<u>MONTHLY CONSUMPTION (kWh)</u>	
			<u>1976-1977</u>	<u>1977-1978</u>
Lights		Jul	--	20,900
Incandescent	19.7	Aug	--	19,570
Fluorescent	11.5	Sep	19,040	13,720
HVAC		Oct	18,770	13,780
Refrigeration	66.0	Nov	20,110	18,800
Fans	26.0	Dec	--	22,850
Pumps	19.4	Jan	20,600	20,340
Other Equipment		Feb	18,810	18,480
Refrigeration	38.3	Mar	22,500	19,560
Food Preparation	13.7	Apr	20,890	19,000
Miscellaneous	12.5	May	20,760	21,310
		Jun	--	20,140

SEASONAL CONSUMPTION (kWh)								
			Summer			Winter		
			Daily	Hourly MIN	Hourly MAX	Daily	Hourly MIN	Hourly MAX
17 Jun 78/14 Jan 78 (Sat)	737	20	37	718	23	35		
18 Jun 78/15 Jan 78 (Sun)	727	21	37	645	22	35		
20 Jun 78/17 Jan 78 (Tues)	624	19	36	580	22	32		
21 Jun 78/18 Jan 78 (Wed)	535	18	32	655	19	34		

Comments:

Enlisted open dining facility occupancy generally from 5 to 12 PM.
 Cooling accomplished by 100-ton AC unit.

Table 27

Building 1949 -- Fort Belvoir

Building Function: Motor pool Location: Fort Belvoir Year Built: 1963
 Building Number: 1949 Floor Area: 11,235 sq ft

BUILDING EQUIPMENT		MONTHLY CONSUMPTION (kWh)	
Type/Description	Approximate Connected Load	1976-1977	1977-1978
Lights		Jul	-- 2,560
Incandescent	1.1	Aug	-- 3,760
Fluorescent	10.9	Sep	-- 3,820
HVAC		Oct	-- 3,430
Fans	10.8	Nov	-- 3,880
Unit heaters	1.6	Dec	-- 4,210
Other Equipment		Jan	5,330 5,060
Air compressor	5.6	Feb	4,100 5,300
Door motors	3.3	Mar	4,290 5,540
Water heater	4.5	Apr	3,400 3,900
Miscellaneous	4.1	May	3,930 5,400
		Jun	2,560 4,210

SEASONAL CONSUMPTION (kWh)								
			Summer			Winter		
			Daily	Hourly MIN	Hourly MAX	Daily	Hourly MIN	Hourly MAX
17 Jun 78/14 Jan 78 (Sat)	12	.2	1			120	5	5
18 Jun 78/15 Jan 78 (Sun)	13	.2	4			122	5	5
20 Jun 78/17 Jan 78 (Tues)	140	.3	15			258	3	21
21 Jun 78/18 Jan 78 (Wed)	132	.5	14			220	2	24

Comments:

Motor pool hours of operation from 7 AM to 5 PM (Monday through Friday).

Table 28

Fort Belvoir -- Electrical Energy Consumption
(in MWh x 10³) for FY77 to FY79

	<u>FY77</u>	<u>FY78</u>	<u>FY79</u>
OCT	6016	5888	7134
NOV	6080	6464	5248
DEC	6400	6112	6624
JAN	6048	6592	6240
FEB	5568	5152	7008
MAR	5856	6592	5280
APR	5792	6016	5856
MAY	5472	5440	6016
JUN	6880	6944	--
JUL	9184	8800	--
AUG	9760	10,688	--
SEP	9088	8480	--


Total: FY77 = 82,144 MWh
FY78 = 83,168 MWh

Table 29

Fort Carson -- Electrical Energy Consumption
(in MWh x 10³) for FY77 to FY79

	<u>FY77</u>	<u>FY78</u>	<u>FY79</u>
OCT	6118	5833	5555
NOV	6203	6162	5994
DEC	6189	5812	6584
JAN	6844	6845	6224
FEB	6457	6419	6000
MAR	5563	5608	5432
APR	5874	5986	6038
MAY	5414	5606	--
JUN	6374	5452	--
JUL	5752	6286	--
AUG	5804	6338	--
SEP	5203	5735	--

Total: FY77 = 71,795,600 MWh
FY78 = 72,085,150 MWh



THIS PAGE IS BEST QUALITY PRACTICABLE
FROM CUT #15

2






Figure 2. Monthly feeder profile -- winter (Fort Carson).





NOTES

1. DETAILS ON THIS DRAWING WERE OBTAINED THROUGH FIELD VISITS AND DRAWINGS MADE AVAILABLE AT THE SITE. EQUIPMENT RATINGS, WINDUP RPT LOGS, WERE NOT AVAILABLE.
2. ALL OTHER SYMBOLS ARE IN CONFORMANCE WITH ANSI STANDARDS C57.1-1970 AND Y31.2-1975

SYMBOL LIST

FUSED DISCONNECT DESIGNATION:

- 1. QUANTITY OF FUSES
- 2. SPEED OF FUSE
- 3. NOMINAL AMP. SIZE

TRANSFORMER BANK DESIGNATION:

- 1. PHASE OF EACH TRANSFORMER
- 2. TRANSFORMER KVA RATING
- 3. NUMBER OF TRANSFORMERS

- 4. SERIES TRIP LINE RECLOSER

- 5. BUILDING OR FACILITY NUMBER

ort Carson.

THIS PAGE IS BEST QUALITY PRACTICABLE
FROM COPY FURNISHED TO EDO

2




Figure 4. Monthly feeder profile -- summer (Fort Carson).




Figure 5. Monthly electrical profile -- winter (Building 1430).




Figure 6. Monthly electrical profile -- summer (Building 1430).




Figure 7. Monthly electrical profile -- winter (Building 1953).




Figure 8. Monthly electrical profile -- winter (Building 2492).




Figure 9. Monthly electrical profile -- winter (Building 2992).




Figure 10. Monthly electrical profile -- summer (Building 2492).




Figure 11. Monthly electrical profile -- summer (Building 2992).

APPENDIX:

BUILDING INSPECTION PROCEDURES

The procedures described in this appendix will help Facilities Engineers develop action plans for the immediate reduction of electrical energy use and to determine actions that can be programmed to reduce electrical energy consumption in the future. The procedures recommend the inspection of selected buildings and indicate actions that should be taken before, during, and after such inspections.

Background

Electrical consumption analyses of selected Army buildings indicate that some buildings consume up to 70 percent of their annual electrical energy during nonduty (unoccupied) hours. Therefore, major energy consumption reduction efforts should be directed toward reducing building base loads. The procedures described in this appendix are a way to identify and reduce building base loads and thereby reduce installation electrical consumption and demands. The attachment to this appendix is a suggested building inspection checklist.

Preinspection

Step 1: Develop a List of Buildings/Facilities To Be Inspected

During a recent study, it was found that some types of Army building categories use more electrical energy per square foot than others.⁴ Table A1 summarizes the results of this study and lists the average portion of an installation inventory that each consumer group fills. In addition, the percent of total installation electrical consumption attributable to each consumer group is listed.

Table A1

Consumer Categories	Area of Post (%)	Electrical Consumption (%)
Community facilities	10	20
Administration/training	10	15
Maintenance/production	10	12
Bachelor housing	30	20
Family housing	30	20
Medical/dental	6	8
Storage	4	2

⁴ B. Sliwinski, Fixed Facilities Energy Consumption Investigation -- Data Analysis, Interim Report E-143/ADA066513 (CERL, February 1979).

From this table, it is concluded that the buildings that offer the greatest potential for immediate reduction in electrical energy are community facilities, administrative/training facilities, and maintenance facilities.

Although other building types also consume considerable electrical energy, the inspection procedures described here were developed primarily for the listed building types. These building types also permit more immediate access to the building, inspections will cause less personnel impact than if they were conducted in living quarters, and they can usually be rapidly inspected.

Bachelor housing could also be inspected using these procedures; however, inspection would be limited to exterior and mechanical rooms, since full access to each room would be required to completely satisfy the requirement for an interior inspection.

The procedures should not be used for family housing. It is suggested a major public awareness program be developed and disseminated among family housing residents. This program should list actions family housing occupants can take to help reduce installation-wide electrical energy consumption.

Step 2: Assistance From Using Organization

A Building Monitor (a responsible individual assigned to the building by the using organization) should participate in the inspection and should be made responsible for reducing electrical energy consumption in his/her respective buildings. The Building Monitor should know what operations are required of building users and what the operational schedules and requirements of the building are.

The Building Monitor's major duties are: (1) to participate in the quick inspection, (2) to physically start or stop major equipment that has scheduled start and stop times, (3) insure building lights are off when the building is unoccupied, (4) monitor and reset thermostats for proper internal temperatures, and (5) report building or equipment deficiencies to the Facilities Engineer.

Step 3: Select or Contract for Inspectors

The inspector should have a practical knowledge of building drawings, interior electrical systems, and HVAC equipment operation; i.e., the individual should be able to trace an electrical branch circuit from the equipment back to a specific switching device and be able to readily identify HVAC equipment and air distribution system types. Where electrical panel boards may have to be opened to determine equipment switches, the inspectors should either be qualified electrical workers or be accompanied by a Facilities Engineer electrician. It is also suggested the inspector be accompanied by the HVAC maintenance mechanic/operator for the building.

Step 4: Develop a Schedule for the Inspection and Assign Inspectors to Specific Buildings

Inspections should be scheduled so that the inspectors can familiarize themselves with the building, building operation, and its HVAC system type. The inspector should contact the Building Monitor to coordinate a joint inspection of the building.

Step 5: Provide Inspectors With Information About the Building

The inspectors should be briefed on any special building requirements, i.e., HVAC system type, special equipment such as computers, special storage requiring controlled temperatures, or special building functions requiring temperature or humidity control (medical, dental, or battery storage). The inspector should have access to the building drawings so he/she can review the floor plan, locate the mechanical rooms, determine if roof-mounted equipment needs to be inspected, and familiarize himself/herself with HVAC system type and design operation.

Step 6: Tools and Instruments for the Inspection

The inspector should consider using the following tools and measuring equipment: clipboards, pad, pencils, screwdrivers, pliers, flashlight, mechanical room keys, thermostat keys, stick-on tape markers, ladder, a light meter, and a pocket insertion thermometer (to determine building temperatures).

Inspection

Exterior Inspections

The inspector should walk around the exterior of the building and note all exterior lights, open windows, doors blocked open and/or materials used to block doors open, operating exterior wall exhaust fans, operating window AC units, cooling towers, or air-cooled condensers. The inspector should also check for sealing or caulking around doors, windows, and other penetrations in the building wall such as pipes, communication wires, or electrical conduits. The outside air temperature and any obstructions (e.g., bird nests or debris) near outdoor air sensors or outside air intake ducts should be noted and recorded. If HVAC equipment, exhaust fans, or air intakes are on the roof, they should also be inspected. (Many of the suggested inspection items do not appear to be directly electrically related. However, energy conservation actions all tie together. For example, if the amount of hot or cold air required to meet a certain indoor temperature can be reduced by sealing and caulking, the electrical energy required to move this smaller quantity of air is also lowered.)

Interior Inspections

1. The inspector should measure the footcandle levels and identify the type of work being performed at three or four locations in the building and record this information on a rough sketch of the floor plan. The inspector should also check closets, mechanical rooms, and hallways for lighting levels and note if lights are left on when these areas are unoccupied. The type of lighting (incandescent, fluorescent, or other) should be recorded. If the building has been delamped, a spot check should be made to insure that ballasts have been disconnected. A spot check should also be made of lighting control -- for example, are all lights in large rooms switched by a single switch? The inspector should determine if additional switching is recommended.

2. The inspector should locate thermostats, record temperature settings, note if the AC or heating system is on, measure and record the room air temperature near the thermostat, and note if the thermostat has set-point temperature limiters or night setback control. If thermostat settings differ from 65°F (18.3°C) in the winter and 78°F (25.5°C) in the summer, the inspector should tell the Building Monitor to reset all thermostats to the appropriate level.

3. The inspector should check for furniture, drapes, carpet, or other foreign material blocking air diffusers or registers; check for open doors between conditioned and nonconditioned spaces; and note if any other major electrical energy-consuming equipment is present (e.g., communication equipment, television sets, vending machines, water coolers). The inspector should also determine whether or not freezer or refrigerating equipment have automatic defrost cycles.

Mechanical Room Inspections

1. The inspector should make a list of all major electrical energy-consuming equipment, noting all operating equipment. This list should identify any equipment that is or has been connected to timeclocks (inspections conducted during this study identified buildings where timeclocks were installed, but had been disconnected). The inspector should also determine which equipment can be shut off during unoccupied hours; e.g., water heaters can usually be shut off for 1 to 2 hours during occupied hours without negatively effecting personnel or equipment. (Major candidates for scheduling are air-handler motors, chillers, air compressors, exhaust fans, exterior lights, hot water heaters, and hot water circulating pumps.) The inspector should locate, identify, and mark switches for each piece of equipment that can be shut off or scheduled, then discuss a schedule for night and weekend shutoff with the Building Monitor.

2. The inspector should check for obvious equipment malfunctions, e.g., slipping or broken belts, dirty filters, excessive vibrations, rubbing or chattering noises, leaking pumps or pipes, wet pipes, wet pipe insulation, oil on the floor, rusted damper operators, or

excessively hot motors. The inspector should also check for blocked or improper damper positions by noting the air-flow condition and air temperature in the supply, return, and outside air ducts. (Inspections conducted during this study revealed totally closed/open and inoperative dampers in air handling systems.) The inspector should also check the setting of the outside air damper by physically observing the vane position and checking the outside air controller setting, if applicable. In most instances, the introduction of outside air should be minimized for energy conservation, consistent with health and safety. The inspector should check and note the supply and return water temperature for the hot and cold decks and observe and note the temperature setting of the hot water heater or converter so decisions can be made during the evaluation of the building in the next two phases.

Inspection Evaluation

Inspector and Building Monitor Requirements

After the inspection is completed, the inspector and Building Monitor should review the filled-out inspection forms to insure that all items have been covered. The inspector's documentation should be as complete as possible to avoid having to re-inspect the building. The inspector should suggest equipment scheduling or other electrical conservation measures to the Building Monitor. Comments on suggested actions should be made on the cover sheet of the inspection forms. These comments should include the inspector's opinion of what the building's major energy consumption problems are and any speculation he/she might make regarding suspected problems. Items that could not be inspected, or items which the inspector did not feel qualified to inspect, should also be noted. The completed inspection forms should be submitted to the Facilities Engineer.

Facilities Engineer

The Facilities Engineer should thoroughly review the inspection forms to determine actions that can be taken immediately, e.g., directing the Building Monitor to prepare a detailed schedule for turning off equipment at night and on weekends, setting back thermostats, or adjusting the building's operating temperatures. Based on the inspection results, the Facilities Engineer should initiate action to procure and install building conservation features such as timeclocks, temperature limiting/setback thermostats, or external monitoring lamps (to indicate operating equipment or radio control of equipment). Malfunctioning equipment should be repaired and improper operating parameters should be adjusted. For example, inspection form entries which show AC fans operating when outdoor temperatures are cool, hot deck temperatures that are high when only AC is required, or high air temperatures in supply ducts when chilled water temperatures are low are indications of specific problem areas.

The Facilities Engineer should also identify buildings where further electrical energy consumption reductions appear possible, but which have system complexities or building abnormalities that preclude a definitive electrical savings analysis and schedule such buildings for further study, including a thorough analysis of system and building operations.

INSPECTION REPORT

Building No. _____

Building Use _____

Date of Inspection _____

Inspector _____

Building Monitor _____

Phone _____

Office Symbol _____

Alternate _____

Phone _____

Office Symbol _____

Comments by Inspector and Building Monitor:

Facilities Engineer Review by _____

Is building scheduled for energy monitoring and control? Yes No

Summary of Facilities Engineer Actions:

Attachment

EXTERIOR SURVEY

<u>ITEM</u>	<u>YES</u>	<u>NO</u>	<u>COMMENTS</u>
Lights on	--	--	
Open windows	--	--	
Doors blocked open	—	—	
Door blocks available	—	—	
Operating equipment	—	—	
Exhaust fans	—	—	
Window AC units	—	—	
Cooling towers	—	—	
Air cooled condensers	—	—	
Other _____	—	—	
	<u>ACCEPT</u>	<u>MARGINAL</u>	<u>BAD</u>
Sealing and caulking			
Doors	—	—	—
Windows	—	—	—
Other penetrations	—	—	—

Outside air temperature: _____

Roof observations:

Equipment items (include voltage and full-load amperage)

Other problem areas:

Attachment

INTERIOR SURVEY

Lighting

<u>Work type/areas</u>	<u>Lighting Level</u>	<u>Incandescent</u>	<u>Fluorescent</u>
1	—	—	—
2	—	—	—
3	—	—	—
4	—	—	—
5 Closets	—	—	—
6 Hallways	—	—	—

Room Switch Control

___ Adequate ___ Inadequate

If delamped, are ballasts disconnected? Yes ___ No ___

If no, indicate location:

Thermostats

<u>Area</u>	<u>Setpoint Temperature</u>	<u>Measured Temperature</u>	<u>Limiters</u>		<u>Setback</u>	
			<u>Yes</u>	<u>No</u>	<u>Yes</u>	<u>No</u>
—	—	—	—	—	—	—
—	—	—	—	—	—	—
—	—	—	—	—	—	—
—	—	—	—	—	—	—

Are night setback thermostats recommended? Yes ___ No ___

Are temperature limiting thermostats recommended? Yes ___ No ___

AC system was: On ___ Off ___

Heating system was: On ___ Off ___

Attachment

Air flow blockages Yes ☐ No ☐
If yes, where:

Doors open between conditioned and nonconditioned spaces: Yes ☐ No ☐

List major electrical energy consuming equipment other than building HVAC within building (indicate voltage and full-load amperage):

Mechanical Equipment Room

Major Items of Equipment	Timeclock Installed		Timeclock Operating		Recommend for Clock Control	
	<u>Yes</u>	<u>No</u>	<u>Yes</u>	<u>No</u>	<u>Yes</u>	<u>No</u>
_____	—	—	—	—	—	—
_____	—	—	—	—	—	—
_____	—	—	—	—	—	—
_____	—	—	—	—	—	—
_____	—	—	—	—	—	—
_____	—	—	—	—	—	—

Attachment

Recommended Schedule (indicate start and stop time)

<u>Equipment Item</u>	<u>Switch Location</u>	<u>Weekday</u>		<u>Weekend</u>	
		<u>Start</u>	<u>Stop</u>	<u>Start</u>	<u>Stop</u>
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____

Observation

Air Flowing

<u>Item</u>	<u>Yes</u>	<u>No</u>	<u>Air Temperature</u>
Supply duct	_____	_____	_____
Return duct	_____	_____	_____
Outside duct	_____	_____	_____

Outdoor air damper position _____

Hot deck supply temperature _____

Hot deck return temperature _____

Cold deck supply temperature _____

Cold deck return temperature _____

Domestic hot water temperature _____

Equipment discrepancies and problem areas:

Attachment

CERL DISTRIBUTION

Chief of Engineers
ATTN: Tech Monitor
ATTN: DAEN-RD
ATTN: DAEN-MP
ATTN: DAEN-ZC
ATTN: DAEN-CW
ATTN: DAEN-RM
ATTN: DAEN-CCP
ATTN: DAEN-ASI-I (2)

US Army Engineer Districts

ATTN: Library
Alaska
Albaton
Albuquerque
Baltimore
Buffalo
Charleston
Chicago
Detroit
Far East
Fort Worth
Galveston
Huntington
Jacksonville
Japan
Jidda
Kansas City
Little Rock
Los Angeles
Louisville
Memphis
Mobile
Nashville
New Orleans
New York
Norfolk
Omaha
Philadelphia
Pittsburgh
Portland
Riyadh
Rock Island
Sacramento
San Francisco
Savannah
Seattle
St. Louis
St. Paul
Tulsa
Vicksburg
Walla Walla
Wilmington

US Army Engineer Divisions

ATTN: Library
Europe
Huntsville
Lower Mississippi Valley
Middle East
Middle East (Rear)
Missouri River
New England
North Atlantic
North Central
North Pacific
Ohio River
Pacific Ocean
South Atlantic
South Pacific
Southwestern

Waterways Experiment Station

ATTN: Library

Cold Regions Research Engineering Lab

ATTN: Library

US Government Printing Office

Receiving Section/Depository Copies (2)

Defense Technical Information Center

ATTN: DDA (12)

Engineering Societies Library

New York, NY

FESA, ATTN: Library

ETL, ATTN: Library

Engr. Studies Center, ATTN: Library

Inst. for Water Res., ATTN: Library

Army Instl. and Major Activities (CONUS)

DARCOM - Div., Instl. & Svcs.

ATTN: Facilities Engineer

ABRADCOR

Aberdeen Proving Ground
Army Mater. and Mechanics Res. Ctr.
Corpus Christi Army Depot
Harry Diamond Laboratories
Dugway Proving Ground
Jefferson Proving Ground
Fort Monmouth
Letterkenny Army Depot
Natick Research and Dev. Ctr.
New Cumberland Army Depot
Pueblo Army Depot
Red River Army Depot
Redstone Arsenal
Rock Island Arsenal
Savannah Army Depot
Sharpe Army Depot
Seneca Army Depot
Tobyhanna Army Depot
Tooele Army Depot
Watervliet Arsenal
Yuma Proving Ground
White Sands Missile Range

FORSCOM

FORSCOM Engineer, ATTN: AFEN-FE

ATTN: Facilities Engineers

Fort Buchanan
Fort Bragg
Fort Campbell
Fort Carson
Fort Devens
Fort Drum
Fort Hood
Fort Indiantown Gap
Fort Irwin
Fort Sam Houston
Fort Lewis
Fort McCoy
Fort McPherson
Fort George G. Meade
Fort Ord
Fort Polk
Fort Richardson
Fort Riley
Presidio of San Francisco
Fort Sheridan
Fort Stewart
Fort Wainwright
Vancouver Bks.

TRADOC

HQ, TRADOC, ATTN: ATEN-FE

ATTN: Facilities Engineer

Fort Belvoir
Fort Benning
Fort Bliss
Carlisle Barracks
Fort Chaffee
Fort Dix
Fort Eustis
Fort Gordon
Fort Hamilton
Fort Benjamin Harrison
Fort Jackson
Fort Knox
Fort Leavenworth
Fort Lee
Fort McClellan
Fort Monroe
Fort Rucker
Fort Sill
Fort Leonard Wood

INSCOM - Ch. Instl. Div.

ATTN: Facilities Engineer

Vint Hill Farms Station
Arlington Hall Station

WESTCOM

ATTN: Facilities Engineer

Fort Shafter

MDW

ATTN: Facilities Engineer

Cameron Station
Fort Lesley J. McNair
Fort Myer

HSC

HQ USAHSC, ATTN: HSC-10
ATTN: Facilities Engineer
Fitzsimons Army Medical Center
Walter Reed Army Medical Center

USACE

ATTN: Facilities Engineer
Fort Huachuca
Fort Ritchie

MTMC

HQ, ATTN: MTMC-SA
ATTN: Facilities Engineer
Oakland Army Base
Bayonne MDI
Sunny Point MDI

US Military Academy

ATTN: Facilities Engineer

USAES, Fort Belvoir, VA

ATTN: FE Mgmt. Br.
ATTN: Const. Mgmt. Br.
ATTN: Engr. Library

Chief Inst. Div., I&SA, Rock Island, IL

USA ARRCOM, ATTN: Div., Instl. & Svc

TARCOM, Fac. Div.

TECOM, ATTN: DRSTE-LG-F

TSARCOM, ATTN: STSAS-F

NARAD COM, ATTN: DRONA-F

AMMRC, ATTN: DRXMR-WF

HQ, XVIII Airborne Corps and

Ft. Bragg

ATTN: AF2A-FE-EE

HQ, 7th Army Training Command

ATTN: AETTG-DEH (5)

HQ USAREUR and 7th Army

ODCS/Engineer

ATTN: AEAEN-EH (4)

V Corps

ATTN: AETVDEH (5)

VII Corps

ATTN: AETSDEH (5)

21st Support Command

ATTN: AEREN (5)

US Army Berlin

ATTN: AEBA-EN (2)

US Army Southern European Task Force

ATTN: AESE-ENG (5)

US Army Installation Support Activity,

Europe

ATTN: AEUES-RP

8th USA, Korea

ATTN: EAFE

Cdr. Fac Engr Act (8)

AFE, Yongsan Area

AFE, 20 Inf Div

AFE, Area II Spt Det

AFE, Cp Humphreys

AFE, Pusan

AFE, Taegu

DLA ATTN: DLA-WI

USA Japan (USARJ)

Ch. FE Div, AJEN-FE

Fac Engr (Honshu)

Fac Engr (Okinawa)

RDK/US Combined Forces Command

ATTN: EUSA-HHC-CFC/Engr

ENR Branch Distribution

Fort Belvoir, VA 22060
ATTN: DRDME-G
ATTN: FESA-TSD
ATTN: MAJ Shurb

Fort Leavenworth, KS 66027
ATTN: ATZLCA-SA/P. Wolcott

USFA APRADCOM
ATTN: DRDAR-LCM-SP

US Army Engineer Districts
ATTN: Chief, Engineer Division

US Army Engineer Divisions
ATTN: Chief, Engineer Division

Naval Facilities Engrg Command
ATTN: Code 032F
ATTN: Code 1023
ATTN: Code 11130
ATTN: Code 044

Naval Civil Engrg Laboratory
ATTN: Code L03AE
ATTN: Code L0RA
ATTN: Code L60

Alexandria, VA 22314
ATTN: DLA-W
ATTN: DRCIS

Army-Air Force Exchange Service
ATTN: Chief, Engineering Div

Andrews AFB, WASH DC 20331
ATTN: AFSC-DEE

McClellan AFB, CA 95652
2852 APG/DE (LT D. Hall)

Patrick AFB, FL 32925
ATTN: XRQ/James T. Burns

Tyndall AFB, FL 32403
ATTN: RD

Wright-Patterson AFB, OH 45433
ATTN: POE

Washington, DC
DCMO (Logistics)
ODAS (EE&S)
ODAS (I&H)
HQDA (DALO-TSE-F) (3)
Office of Planning & Dev, OREPM
Director, Bldg Technology & Safety Div
Public Building Service
Assistant Sec for Conservation & Solar Energy
Assistant Sec for Resource Applications
National Institute of Building Sciences
Director, Center for Building Technology
Energy Research and Development Foundation

Oak Ridge, TN 37830
Department of Energy

Mindingland, Larry M

An analysis of electrical consumption at representative Army installations. --
Champaign, IL : Construction Engineering Research Laboratory ; Springfield, VA :
available from NTIS, 1980.

77 p. ; 27 cm. (interim report ; E-163)

1. Electric power. 2. Energy consumption. 3. Military posts-energy consumption. I. Title. II. Series: U.S. Army Construction Engineering Research Laboratory. Interim report ; E-163.

LMED
-8